

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

RECEIVED
 APR 14 1969
 STATE OF OREGON
 (Please type or print)
 (Do not write above this line)
RECEIVED
 MAY 5 1969
 STATE ENGINEER
 SALEM OREGON

Well No. 6N/35-34 bac
 Permit No. G-4865 well # 7

(1) OWNER:

Name JAMES A. REESE
 Address Rd. 2, Box 336 - Milton Freewater, OREGON

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
 8" Diam. from 0 ft. to 84 ft. Gage 250
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No

Type of perforator used:

Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
 Type Model No.
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 53 ft. below land surface Date May 1, 1969
 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

AIR TEST: "250 GPM"

(Note: Well is supposed to be pump tested in the near future.)

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used cement

Depth of seal 45 feet in clay ft.

Diameter of well bore to bottom of seal 12 in.

Were any loose strata cemented off? Yes No Depth 0 to 45'

Was a drive shoe used? Yes No

Did any strata contain unusable water? Yes No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? Yes No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Umatilla Driller's well number
 1/4 Section 34 T. 6N R. 35 E. W.M.
 Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 350 ft. Depth of completed well 350 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
soil brown	0	3	
Boulders, gravel coarse	3	40	
clay, brown	40	50	
Gravel, coarse caving	50	65	
Cemented Gravel med.	65	277	
Cemented gravel coarse	277	335	
Sand, very fine	335	350	

Work started Feb. 26 1969 Completed Mar. 5 1969

Date well drilling machine moved off of well Mar. 5 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] [Signature] Date Mar 20, 1969
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 640

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Project Corporation (Type or print)

Address Rd. 2, Box 134-B - Milton-Freewater, OREGON

[Signed] [Signature] (Water Well Contractor)

Contractor's License No. 512 Date MAR. 28, 1969