

RECEIVED

WATER WELL REPORT STATE OF OREGON

JUN 19 1981

WATER RESOURCES DEPT
SALEM, OREGON

UMAT
5051

State Well No. 6/35E-35

State Permit No.

(1) OWNER:

Name John LeFore
Address Rt 4 Box 277 MFore 97862
City Milton Freewater State Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
Rotary Mud Dug
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other
Thermal: Withdrawal ReInjection

(5) CASING INSTALLED:

Steel Plastic
10" Diam. from +1 ft. to 20" ft. Gauge 0250
" Diam. from ft. to ft. Gauge

(6) LINER INSTALLED:

8" Diam. from 0 ft. to 200 ft. Gauge Sch 160 pvc

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Rotator
Size of perforations 1 in. by 1 in. liner
900 perforations from 50 ft. to 200 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
gal./min. with ft. drawdown after hrs.
Air test 200 gal./min. with drill stem at 195 ft. 2 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 56 Depth artesian flow encountered ft.

(10) CONSTRUCTION:

Special standards: Yes No
Well seal—Material used Cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 15 sacks
How was cement grout placed? Pumped

Was pump installed? no Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Umitilla Driller's well number
¼ Section 35 T. 6 R. 35E W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: RT 4 Box 277 MFore

(12) WATER LEVEL: Completed well.

Depth at which water was first found 40 ft.
Static level 21 ft. below land surface. Date 6-2-81
Artesian pressure lbs. per square inch. Date

(13) WELL LOG:

Diameter of well below casing 10
Depth drilled 203 ft. Depth of completed well 198 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Rock and Topsoil			
large boulders.	0	3	
Gray boulders and gravel	3	18	
Brown hars pan and boulders	18	24	
Tan hard pan and gravel	24	27	
Brn hard pan and boulders	27	31	
Tan hard pan and gravel	31	45	20
Dark Brn hard pan and gravel	45	54	20
Light Brown hard pan and gravel	54	57	21
Tan hard pan and boulders	57	120	20
Light brown hard pan and gravel	120	123	20
Tan hard pan and gravel	123	125	20
Brown sand hard pan	125	127	
Brn hard pan sand and gravel	127	184	20
Brn Hard pan sand and red rocks	184	203	20

Work started 5-28 19 81 Completed 6-1-81 19
Date well drilling machine moved off of well 6-2-81 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Joseph J. LaPorte Date 6-2-81
(Drilling Machine Operator) 1298
Drilling Machine Operator's License No.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
LaPorte Well Drilling
Name (Person, firm or corporation) (Type or print)
Address Rt 1 Box 101 MFore
[Signed] Joseph J. LaPorte
(Water Well Contractor)
Contractor's License No. 256 Date 6-2-81 19

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*12658-690