

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

OCT 6 1965

WATER WELL REPORT

UMAT 5073

State Well No.

6N/35-35 N

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON STATE ENGINEER (Please type or print)

G-4059

State Permit No.

(1) OWNER:

Name James C. Smith
Address Winesap Rd. Route 2 - Box 364
Milton-Freewater, Oregon

(2) LOCATION OF WELL:

County Umatilla Driller's well number
1/4 1/4 Section 35 T. 6 N R. 35 E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [] Deepening [x] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [x] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [x] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [x]

8" Diam. from 16 ft. to 43 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [] Yes [x] No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [x] No

Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Concrete
Depth of seal 2 ft. Was a packer used? No
Diameter of well bore to bottom of seal 7 in.
Were any loose strata cemented off? [] Yes [x] No Depth
Was a drive shoe used? [x] Yes [] No
Was well gravel packed? [] Yes [x] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [x] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 22 ft. below land surface Date 8/30/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [x] Yes [] No If yes, by whom? Owner
Yield: 90 gal./min. with 17 ft. drawdown after 6 hrs.

Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date

Temperature of water 62 Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 62 ft. Depth of completed well 80 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include Small Boulders (18-28), Coarse gravel & med. sand (28-36), Gray clay & coarse gravel (36-80).

Work started 8/11 1965 Completed 9/5 1965
Date well drilling machine moved off of well 9/5 1965

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME E. M. J. Behrens (Type or print)
Address P.O. Box 201 - Milton-Freewater, Oregon
Drilling Machine Operator's License No. XXIX 124
[Signed] E.M.J. Behrens (Water Well Contractor)
Contractor's License No. 229 Date 10/5 1965