

**WATER WELL REPORT
STATE OF OREGON**

*UMAT
5197*

RECEIVED

APR 9 1984

State Well No. *6W/36E-3006*

Water Resources Dept. State Permit No. _____

SALEM, OREGON

(1) OWNER:

Name WAYNE HOCKETT
Address Rt 1 Box 148 D2
City Milton-Freewater State Oreg

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
Rotary Mud Dug
Cased Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other
Thermal: Withdrawal Reinjection

(5) CASING INSTALLED:

Steel Threaded Plastic Welded

6" Diam. from 7 1/2 ft. to 59 ft. Gauge 0.250
" Diam. from _____ ft. to _____ ft. Gauge _____

LINER INSTALLED: None

" Diam. from _____ ft. to _____ ft. Gauge _____

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____

Size of perforations in by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Type _____

Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.

Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Water pump test made? Yes No If yes, by whom? _____

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

Air test 100 gal./min. with drill stem at 123 ft. 1 hrs.

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow _____ g.p.m.

Temperature of water 57° Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used 1/6

Well sealed from land surface to _____ ft.

Diameter of well bore to bottom of seal _____ in.

Diameter of well bore below seal _____ in.

Number of sacks of cement used in well seal _____ sacks

How was cement grout placed? _____

Was pump installed? no Type _____ HP _____ Depth _____ ft.

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.

Did any strata contain unusable water? Yes No

Type of Water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? Yes No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

NOTICE TO WATER WELL CONSTRUCTOR

The original and first copy of this report
is to be filed with the _____

(10) LOCATION OF WELL:

County Umatilla Driller's well number _____
NW 1/4 SW 1/4 Section 30 T. 6N R. 36E W.M.
Tax Lot # _____ Lot _____ Blk _____ Subdivision _____

Address at well location: _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found _____ 110 ft.

Static level 12 ft. below land surface. Date _____

Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing _____ 6

Depth drilled 125 ft. Depth of completed well 125 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u>GRAVEL</u>	<u>45</u>	<u>51</u>	
<u>BELOW GRAVEL</u>	<u>51</u>	<u>125</u>	

Work started 3-21-1979 Completed 3-22-1979

Date well drilling machine moved off of well 3-22-1979

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] _____ Date _____, 19____

Bonded Water Well Constructor Certification:

Bond _____ Issued by: _____ Surety Company Name _____

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name LADD Horn Well Drilling (Type or print)

Address Rt 1 Box 17 Palat Rock, Oreg 97861

[Signed] _____ Date _____, 19____

Water Well Constructor _____

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310

SP-15292-690