NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT, SALEM, OREGON
within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

UMAT 5199

UMAT 5199

State Well No. 6N/36E-30bb

State Permit No.

RECEIVED
JUN 15 1979
WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER:
Name L.E. Von Der Ahe
Address RT# 1 Box 145
Milton-Freewater, OR 97862

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒
8" Diam. from plus 1 ft. to 130 ft. Gage 0.250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Torch
Size of perforations 3/8 in. by 14 in.
64 perforations from 90 ft. to 130 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 54° Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 5 sacks
How was cement grout placed? Pumped
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Umatilla Driller's well number
NW ¼ NW ¼ Section 30 T. 6N R. 36 E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 85 ft.
Static level 39 ft. below land surface. Date 3-3-79
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 8
Depth drilled 150 ft. Depth of completed well 140 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil, Gravel	0	10	
Clay, Gravel Boulders	10	35	
Gravel, Boulders	35	85	
Cement Gravel & Boulders	85	150	39'

RECEIVED
MAR 28 1979
WATER RESOURCES DEPT.
SALEM, OREGON

Work started 3-2-79 19 Completed 3-3-79 19
Date well drilling machine moved off of well 3-5-79 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Todd Horn (Drilling Machine Operator) Date 3-7, 1979
Drilling Machine Operator's License No. 1345

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name C.W. Summers Well Drilling (Person, firm or corporation) (Type or print)
Address Rt #3 Box 143-A-1 M & F OR 97862
[Signed] Clarence W. Summers (Water Well Contractor)
Contractor's License No. 575 Date 3-7-79, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119