

RECEIVED
AUG 20 1968

RECEIVED
SEP 01 1968

UMAT
5230

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT
STATE ENGINEER STATE OF OREGON
SALEM, OREGON
State Well No. 6/36-31N
State Permit No. 426

(1) OWNER:
Name Waldo Bradshaw
Address Route 1 - Box 178B
Milton-Freewater, Oregon

(2) LOCATION OF WELL:
County Umatilla Driller's well number
1/4 Section 31 T. 6 R. 36 E.W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
Threaded Welded
8" Diam. from 0 ft. to 403 ft. Gage 250
6" Diam. from 400 ft. to 500 ft. Gage 250

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Puddled Bentonite
Depth of seal 30 ft. Was a packer used? No
Diameter of well bore to bottom of seal 11 1/2 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 220 ft. below land surface Date 7/29/63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 180 gal./min. with 40 ft. drawdown after 1 hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 66 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 545 ft. Depth of completed well 545 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Gray clay & gravel	0	60
Red clay	60	63
Red clay & gravel	63	106
Gravel & red clay	106	148
Clay, black & gravel	148	186
Gray clay & gravel	186	210
Boulders	210	213
Gray clay & coarse gravel	213	251
Med. gravel & gray clay	251	260
Red clay & med. gravel	260	345
Gray clay & med. gravel	345	387
Gray clay	387	402
Gray clay & small boulders	402	450
Gray clay	450	467
Gray clay & med. boulders	467	500
Boulders & gray clay	500	520
Boulders	520	545

Work started 2/17 1963. Completed 7/29 1963
Date well drilling machine moved off of well 7/29 1963

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME E. M. J. Behrens
(Person, firm or corporation) (Type or print)
Address P.O. Box 201 - Milton-Freewater, Oreg.
Drilling Machine Operator's License No. 124
[Signed] E M J Behrens
(Water Well Contractor)
Contractor's License No. 229 Date 8/19, 1963