RECEIVED
SEP 1961
STATE ENGINEER
SALEM, OREGON

UMAT
5232

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. 6N/36-31 E

State Permit No.

(1) OWNER:
Name MARVIN TIMMONS
Address R1 BOX 149
MILTON, OREGON

(2) LOCATION OF WELL:
County UMATILLA Owner's number, if any—
¼ N.W. ¼ Section T. 6N R. 36 E.W.M.
Bearing and distance from section or subdivision corner
from the S.W. Corner of N.W Quarter of Sec. 31 664 ft East. then 180 ft North

(3) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☑ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☑ Welded ☐
6" Diam. from 0 ft. to 44½ ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☐ Yes ☑ No
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? ☐ Yes ☑ No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 46 ft. below land surface Date 9-4-61
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] Marvin Timmons Date 9-4, 1961
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 45 gal./min. with 2 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☑ No

(12) WELL LOG: Diameter of well 6 inches.
Depth drilled 84 ft. Depth of completed well 84 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
SOIL-BROWN-SILTY	0	44
COARSE CONGLOMERATE	44	75
WATER-COURSE-MEDIUM-CONGLOMERATE	75	84

Work started Sept 9 1952 Completed Sept 16 1952

(13) PUMP:
Manufacturer's Name Peerless
Type: Centrifugal H.P. 3

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME EARL G. SHORTRIDGE (Person, firm, or corporation) (Type or print)
Address R-3 BOX 348 MILTON-FREEWATER
Driller's well number
[Signed] Earl G. Shortridge (Well Driller)
License No. 156 Date Sept 4, 1961

(USE ADDITIONAL SHEETS IF NECESSARY)