

UMAT 5267

UMAT 5267

MAY 8 1989

RECEIVED

JUN 1 1989

5/31/89 4062

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

WATER RESOURCES DEPT. SALEM, OREGON

WATER RESOURCES DEPT. SALEM, OREGON

(1) OWNER: Name Walf Powell, Address Rt #1 Box 21, City Milfont, State OR, Zip 97862

(9) LOCATION OF WELL: County Grant, Township 5, Section 18, Range 36, E or W, WM. Street Address of Well (or nearest address) Same

(2) TYPE OF WORK: [X] New Well, [] Deepen, [] Recondition, [] Abandon

(10) STATIC WATER LEVEL: 34 ft. below land surface. Date 4-21-89

(3) DRILL METHOD: [X] Rotary Air, [] Rotary Mud, [] Cable, [] Other

(11) WELL LOG: Ground elevation

(4) PROPOSED USE: [] Domestic, [] Community, [] Industrial, [X] Irrigation, [] Thermal, [] Injection, [] Other

Table with columns: Material, From, To, WB?, SWL. Rows include Soil, Gravel, Gravel + Clay, Basalt Gray Frag, 11 Hard, 11 Med, 11 BRN, 11 GRAN, 11 BRN, 11 GRAY HARD, 11 FRAC, 11 GRAY HARD.

(5) BORE HOLE CONSTRUCTION: Depth of Completed Well 142 ft.

Table with columns: HOLE Diameter, SEAL Material, Amount (sacks or pounds). Rows show seal details for 10, 8, and 6 inch diameters.

How was seal placed? Method [] A [] B [X] C [] D [] E. Backfill placed from... Gravel placed from...

Application No. 611997 Permit No. G11310

(6) CASING/LINER: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Casing: 6, 7, 39, 2.50

Final location of shoe(s)

(7) PERFORATIONS/SCREENS: [] Perforations, [] Screens. Method, Type, Material. Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner.


Date started 4-20-89 Completed 4-21-89

(8) WELL TESTS: Minimum testing time is 1 hour. [] Pump, [] Bailer, [X] Air, [] Flowing Artesian. Yield gal/min 30, Pumping level, Drill stem at 140, Time 1 hr.

(unbonded) Water Well Constructor Certification: I constructed this well in compliance with Oregon well construction standards...

Temperature of water 58 degrees, Depth Artesian Flow Found, Was a water analysis done? [] Yes, [] No, By whom NONE, Did any strata contain water not suitable for intended use? [] Too little, [] Salty, [] Muddy, [] Odor, [] Colored, [] Other NO, Depth of strata:

(bonded) Water Well Constructor Certification: I accept responsibility for construction of this well and its compliance with all Oregon water well standards. Signed Charles Summers, Date 4-29-89, Company Summers Drilling Co. Job No.



“START CARD”
NOTICE OF BEGINNING OF WELL CONSTRUCTION
(as required by ORS 537.762)

WATER RESOURCES DEPT.
SALEM, OREGON

This form must be completed, signed by both the owner (or authorized agent) and constructor, and the original delivered to the Water Resources Department prior to commencement of construction, alteration or abandonment of each well.

Owner's Name and Mailing Address Walt Powell
Rt # 1 Box 21
Milton Free Water, OR 97862

Proposed Commencement Date 4-14-89

Proposed Well Depth 150, Diameter 6
and Use:
 Domestic Community Industrial Irrigation
 Thermal Injection Other _____

Proposed Well Location: County Umatilla
Township 5 (N or S) Range 30 (E or W) Section 18

At least 2 of these must be provided

1. C 1/4 of 0 1/4 of above section
2. street address of same well location _____
3. tax lot number of well location _____
4. attach approved map with location identified.
(see reverse of this form for approved maps)

We hereby certify that we have read the back of this form, and that to the best of our knowledge the information provided herein is accurate and the well is being properly located from septic tanks and septic drain fields.

x Walt Powell
Owner's Signature

x Charme Summers
Bonded Water Well Constructor

Owner
Title
4-12-89
Date

License No. 575

Company Charme Summers Well Drilling

Note: This is not a Water Right application. The owner is responsible for obtaining a Water Right through the Water Resources Department if required.