

STATE ENGINEER WATER WELL REPORT UMAT
SALEM, OREGON STATE OF OREGON 530

State Well No. 2N/32-2A (15) *cc'd*
 State Permit No. _____

File Original and
 First Copy with the
 STATE ENGINEER,
 SALEM, OREGON

(1) OWNER:

Name City of Pendleton
 Address Pendleton, Oregon

(2) LOCATION OF WELL:

County Umatilla Owner's number, if any—Park Well
SW ¼ SW ¼ Section 2 T. 2N R. 32 E. W.M.
 Bearing and distance from section or subdivision corner
NE corner of Block 22 bordered by SE 5th,
SE Byers, SE 4th and the Umatilla River Levee
Block 22 Addition, Original Town of Pendleton

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
30" Diam. from 1 ft. to 10 ft. Gage $\frac{3}{8}$ "
24" Diam. from 0 ft. to 185' 10" ft. Gage $\frac{3}{8}$ "
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used _____
 SIZE of perforations in. by in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Was a surface seal provided? Yes No To what depth? 185 ft.
 Material used in seal— Neat cement annular seal
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 162' 2" ft. below land surface Date _____
 Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by: _____

[Signed] Andrew J. Bromberg Date 12-1, 1958
 City Manager (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? Midco
 Yield: 2400 gal./min. with 85' 6" ft. drawdown after 45 hrs.
 " " " " " "
 " " " " " "
 Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow g.p.m. Date _____
 Temperature of water 60° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 30 x 24 x 20 x 16 inches
 Depth drilled 700 ft. Depth of completed well 700 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Soft black topsoil	0	1
Hard black boulders	1	4
Med. hard grey boulders	4	10
Dark hard basalt	10	53
Soft brown clay	53	66
Clay & broken basalt	66	68
Med. dark broken basalt	68	116
Hard dark basalt	116	131
Soft red and green clay	131	134
Medium black basalt	134	154
Soft black clay & broken rock	154	158
Medium dark broken rock	158	177
Dark hard basalt	177	195
Dark Medium broken basalt	195	210
Dark medium basalt	210	224
Dark hard basalt	224	288
Dark medium basalt	288	300
Soft brown cinders	300	310
Dark medium basalt	310	320
Brown medium basalt	320	347
Dark hard basalt	347	352
Medium brown basalt	352	354
Medium dark basalt	354	385
Medium brown basalt	385	392

(see attached sheet)

Work started May 20 1958. Completed Oct. 24 1958

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Midland Drilling Co.
 (Person, firm, or corporation) (Type or print)

Address P. O. Box 637, Walla Walla, Washington

Driller's well number 10

[Signed] E. J. Jungmann
 (Well Driller) E. J. Jungmann, V. P.

License No. 236 Date Nov. 21, 1958

CITY OF PENDLETON, OREGON
UMAT 530
 AQUIFER TEST

2N/32-2 ccd
~~DK~~

DATE 11.15.60

SHEET 1 OF 5

DATE	TIME	ACCUM. MINUTES	BAROM. CORRECTION FROM 4:46 P.M. 9/20/60 FEET WATER	WELLS AND ZERO WATER ELEVATIONS - M.S.L.				REMARKS			
				909.18		909.20			906.16	907.16	
				STILLMAN		BYERS			BANK	ROUND-UP	
				DRAWDOWN FEET	Q-G.P.M.	DRAWDOWN FEET	Q-G.P.M.	DRAWDOWN FEET	DRAWDOWN FEET		
			100%							906.16	
9/20	4:46 ^P	0	0	0	START						STATE HOSPITAL AND 21 ST STREET PUMPS STOPPED 3:54 PM STILLMAN ON 4:45 PM
	:47	1	0	56.13	2400						
	:51	5	0	66.13	2500						
	:57	11	0	68.13	2500						
	5:03	17	0	68.63	2480						
	:10	24	0	69.30	2480						
	:19	33	0			0	-				
	:26	40	0						0		
	7:27	161	0	70.63	2430						
	:35	169	0								
	:46	180	0								
	8:32	232	+0.01	70.62	2420						
	10:54	368	0.02	70.60	2410						
	11:00	374									
	:10	384									
	:31	405	0.03	70.38	2400						
9/21	6:55 ^A	845	0.08	70.30	2400						
	8:43	957	0.00	70.42	2400						
	9:00	974	0.00			0.66	-				
	:30	1004	0.09						+0.09		
	3:40 ^P	1374	-0.02						-0.06		
	4:00	1394	-0.02	70.65	2400						
	:25	1410	-0.02			0.69	-				
	:45	1439	-0.02	70.65	2400						
	5:00	1454									
	9:25	1719									
	:45	1739	-0.01	70.39	2400						
	:55	1749									
9/22	7:40 ^A	2334	-0.06							-1.27	
	8:05	2359	-0.06			0.80	-				
	:25	2379	-0.05	70.77	2400						
	2:30 ^P	2744	-0.21	70.13	2400				0.21		
	7:05	3019	-0.25							-0.83	
	:15	3029	-0.25	71.17	2400				0.19		
	:25	3030	-0.25			0.92	-				
9/23	7:15 ^A	3740	-0.19							-1.06	
	8:15	3809	-0.15	70.75	2400				0.09		
	:30	3824	-0.15			0.98	-				
	7:00 ^P	4454	-0.14							-1.03	

CH2M
 CORNELL, HOWLAND HAYES & MERRIFIELD
 1110 N. BROADWAY

1053

CITY OF PENDLETON, OREGON
UMAT 530
 AQUIFER TEST

DATE 11.15.60 100%

SHEET 2 OF 5

DATE	TIME	ACCUM. MINUTES	BAROM. CORRECTION FROM 4:46 P.M. 9/20/60 FEET WATER	WELLS AND ZERO WATER ELEVATIONS - M.S.L.						REMARKS	
				909.18		909.20		906.16	907.18		906.16
				STILLMAN		BYERS		BANK	ROUND-UP		
				DRAWDOWN FEET	Q - G.P.M.	DRAWDOWN FEET	Q - G.P.M.	DRAWDOWN FEET	DRAWDOWN FEET		
9/23	7:15 ^P	4469	-0.14	70.60	240 ⁻			0.11			
	:30	4484	-0.14			0.89	-				
9/24	7:07 ^A	5181	-0.14						-1.03		
	:55	5229	-0.12	70.17	240 ⁻			0.13			
	8:05	5239	-0.12			0.78	-			STILLMAN	
		(40 mins)								"Q"	
9/24	8:45 ^A	0	-0.11	101.54	3000 ⁻			0.11		INCREASED	
	9:00	15	-0.11			0.82	-		-1.06		
	:45	60	-0.12	102.21	2975			0.62			
	10:45	120	-0.12	102.30	2915			0.78			
	11:00	135	-0.12			0.95	-		-0.55		
	:45	180	-0.11	102.41	2910			0.85			
	12:45 ^P	240	-0.10	102.69	2900 ⁺			0.90			
	1:00	255	-0.10			1.02	-		-0.48		
	:45	300	-0.10	102.69	2900 ⁺			0.94			
	2:45	360	-0.12	102.71	2900 ⁺			0.97			
	3:00	375	-0.12			1.04	-		-0.46		
	4:45	480	-0.14	102.98	2900 ⁺			1.00			
	5:00	495	-0.14			1.14	-		-0.44		
	6:45	600	-0.16	105.00	2900 ⁺			1.02			
	7:00	615	-0.16			1.16	-		-0.42		
	8:45	720	-0.16	105.09	2900 ⁺			1.03			
	9:00	735	-0.16			1.08	-		-0.42		
9/25	7:05 ^A	1345	-0.08						-0.42		
	8:00	1395	-0.07	105.66	2900 ⁺			1.04			
	:20	1415	-0.07			1.15	-				
	6:50 ^P	2045	-0.09						-0.33		
	7:45	2100	-0.09	105.68	2900			1.09			
	8:00	2115	-0.09			1.17	-				
9/26	7:05 ^A	2780	-0.03						-0.22		
	8:00	2835	-0.03	105.81	2900			1.10			
	:20	2855	-0.03			1.20	-				
	7:00 ^P	3435	-0.10						-0.32		
	:10	3505	-0.10	106.25	2900			1.14			
	:20	3515	-0.10			1.27	-				
9/27	7:00 ^A	4215	-0.02						-0.31		
	:50	4265	-0.01	106.08	2900			1.12			
	8:05	4280	-0.01			1.26	-				
	11:50	4535	-0.03	106.01	2900			1.14			
	2:30 ^P	4665	-0.08	105.98	2890			1.16			

CITY OF PENDLETON, OREGON
UMAT 530
 AQUIFER TEST

DATE 11.15.60 100%

SHEET 2 OF 5

DATE	TIME	ACCUM. MINUTES	BAROM. CORRECTION FROM 4:46 P.M. 9/20/60 FEET WATER	WELLS AND ZERO WATER ELEVATIONS - M.S.L.						REMARKS	
				909.18		909.20		906.16	907.18		906.16
				STILLMAN		BYERS		BANK	ROUND-UP		
				DRAWDOWN FEET	Q - G.P.M.	DRAWDOWN FEET	Q - G.P.M.	DRAWDOWN FEET	DRAWDOWN FEET		
9/23	7:15 ^P	4469	-0.14	70.60	240 ⁻			0.11			
	:30	4484	-0.14			0.89	-				
9/24	7:07 ^A	5181	-0.14						-1.03		
	:55	5229	-0.12	70.17	240 ⁻			0.13			
	8:05	5239	-0.12			0.78	-			STILLMAN	
		(40 mins)								"Q"	
9/24	8:45 ^A	0	-0.11	101.54	3000 ⁻			0.11		INCREASED	
	9:00	15	-0.11			0.82	-		-1.06		
	:45	60	-0.12	102.21	2975			0.62			
	10:45	120	-0.12	102.30	2915			0.78			
	11:00	135	-0.12			0.95	-		-0.55		
	:45	180	-0.11	102.41	2910			0.85			
	12:45 ^P	240	-0.10	102.69	2900 ⁺			0.90			
	1:00	255	-0.10			1.02	-		-0.48		
	:45	300	-0.10	102.69	2900 ⁺			0.94			
	2:45	360	-0.12	102.71	2900 ⁺			0.97			
	3:00	375	-0.12			1.04	-		-0.46		
	4:45	480	-0.14	102.98	2900 ⁺			1.00			
	5:00	495	-0.14			1.14	-		-0.44		
	6:45	600	-0.16	105.00	2900 ⁺			1.02			
	7:00	615	-0.16			1.16	-		-0.42		
	8:45	720	-0.16	105.09	2900 ⁺			1.03			
	9:00	735	-0.16			1.08	-		-0.42		
9/25	7:05 ^A	1345	-0.08						-0.42		
	8:00	1395	-0.07	105.66	2900 ⁺			1.04			
	:20	1415	-0.07			1.15	-				
	6:50 ^P	2045	-0.09						-0.33		
	7:45	2100	-0.09	105.68	2900			1.09			
	8:00	2115	-0.09			1.17	-				
9/26	7:05 ^A	2780	-0.03						-0.22		
	8:00	2835	-0.03	105.81	2900			1.10			
	:20	2855	-0.03			1.20	-				
	7:00 ^P	3435	-0.10						-0.32		
	:10	3505	-0.10	106.25	2900			1.14			
	:20	3515	-0.10			1.27	-				
9/27	7:00 ^A	4215	-0.02						-0.31		
	:50	4265	-0.01	106.08	2900			1.12			
	8:05	4280	-0.01			1.26	-				
	11:50	4535	-0.03	106.01	2900			1.14			
	2:30 ^P	4665	-0.08	105.98	2890			1.16			

CITY OF PENDLETON, OREGON
UMAT 530
 AQUIFER TEST

DATE 11.15.60. 100%

SHEET 3 OF 5

DATE	TIME	ACCUM. MINUTES	BAROM. CORRECTION FROM 4:46 P.M. 9/20/60 FEET WATER	WELLS AND ZERO WATER ELEVATIONS - M.S.L.				REMARKS			
				909.18		909.20			906.16	907.15	
				STILLMAN		BYERS			BANK	ROUND-UP	
				DRAWDOWN FEET	Q - G.P.M.	DRAWDOWN FEET	Q - G.P.M.	DRAWDOWN FEET	DRAWDOWN FEET		
9/27	2:45 ^P	4680	-0.09							-0.33	
	3:15	4710	-0.09			1.22	-				POWER OUTAGE
	4:52	4807	-0.10	103.69	2900			1.16			
	6:55	4950	-0.10							-0.32	
	7:13	4968	-0.10	104.53	2900			1.18			
	7:25	4980	-0.10			1.27	-				
9/28	7:05 ^A	5660	-0.07							-0.26	
	9:05	5720	-0.06	105.11	2900			1.21			
	9:25	5740	-0.06			1.31	-				
	11:50	5945	-0.08	105.15	2900			1.22			
	3:15 ^P	6150	-0.15	105.16	2900			1.24			
	3:20	6155	-0.15							-0.27	
	4:00	6195	-0.16			1.49	2150				BYERS PUMP ON
	4:10	6205	-0.16	105.17	2900	19.45	2150	1.24			
	4:20	6215	-0.16	105.17	2900	20.27	2100	1.24			
	4:30	6225	-0.16	105.25	2900	21.87	2100	1.24			
	4:40	6235	-0.17	105.26	2900	22.71	2100	1.25			
	4:50	6245	-0.17	105.35	2900	23.30	1850	1.25			
	5:00	6255	-0.17	105.35	2900	23.55	1850	1.25			
	5:20	6275	-0.17							-0.25	
	6:00	6315	-0.18	105.52	2900			1.28			
	6:10	6325	-0.18			24.72	1800				
	6:25	6340	-0.18							-0.24	
	7:00	6375	-0.17	105.68	2900			1.31			
	7:10	6385	-0.17			25.54	1750				
	7:25	6400	-0.17							-0.25	
	8:00	6435	-0.17	105.76	2900			1.36			
	8:12	6447	-0.17			25.79	1700				
	8:25	6460	-0.17							-0.25	
	9:00	6495	-0.17	105.76	2900			1.39			
	9:10	6505	-0.17			26.04	1700				
	9:20	6515	-0.17							-0.16	
	10:00	6555	-0.17	105.85	2900			1.42			
	10:13	6565	-0.17			25.50	1700				
	10:24	6570	-0.17							-0.16	
9/29	12:45 ^A	6715	-0.16							-0.01	
	1:50	6725	-0.16	106.31	2900			1.47			
	1:20	6755	-0.16			25.37	1700				
	2:40	6835	-0.17							0	
	2:50	6845	-0.17	106.40	2900			1.51			

CITY OF PENNINGTON, OREGON
AQUIFER TEST

DATE 11.15.60 100%

SHEET 4 OF 5

DATE	TIME	ACCUM. MINUTES	BAROM. CORRECTION FROM 4:46 P.M. 9/20/60 FEET WATER	WELLS AND ZERO WATER ELEVATIONS - M.S.L.						REMARKS	
				909.18		909.20		906.16	907.16		906.16
				STILLMAN		BYERS		BANK	ROUND-UP		
				DRAWDOWN FEET	Q - G.P.M.	DRAWDOWN FEET	Q - G.P.M.	DRAWDOWN FEET	DRAWDOWN FEET		
9/29	3:20 ^A	6875	-0.17			26.38	1650				
	4:40	6955	-0.17						0		
	5:00	6965	-0.17	106.18	2900			1.54			
	5:20	6995	-0.17			26.54	1675				
	7:05	7100	-0.16						-0.01		
	8:00	7155	-0.15	106.24	2900			1.57			
	8:12	7167	-0.15			27.19	1725				
	8:20	7185	-0.24			28.53	1725				
	8:30	7245	-0.24	106.25	2900			1.64			
	8:45	7260	-0.20						+0.03		
	7:00	7315	-0.27						+0.10		
	7:14	7329	-0.27	106.25	2900			1.68			
	7:30	7345	-0.27			28.56	1700				
9/30	7:05 ^A	7540	-0.27						+0.10		
	7:55	8590	-0.28	106.51	2900			1.77			
	8:15	8610	-0.28			28.07	1700				
	2:10 ^P	8965	-0.38			29.84	1800				
	2:20	8975	-0.38	107.20	2900			1.80			
	2:30	8985	-0.38						+0.13		
	6:50	9245	-0.41						+0.16		
	7:00	9255	-0.41	106.56	2900			1.82			
	7:20	9275	-0.41			28.70	1650				
10/1	7:05 ^A	9580	-0.25						+0.17		
	7:55	10030	-0.25	106.90	2900			1.85			
	8:00	10035	-0.25			28.21	1750				
	5:20 ^P	10595	-0.29						+0.21		
	5:30	10605	-0.29	106.94	2900			1.89			
	5:50	10625	-0.29			28.75	1650				
10/2	7:05 ^A	11420	-0.18						+0.26		
	7:40	11455	-0.18	107.00	2900			1.83?			
	8:10	11485	-0.18			28.55	1650				
	10:15	11610	-0.18	107.06	--	25.72	--	1.86		STILLMAN STOPPED. BYERS STOPPED.	
10/2	10:15 ^A	0	-0.18	107.06	--	15.64	--				
	10:25	10	-0.18	3.81	--	13.74	--				
	10:35	20	-0.18	2.75	--	13.49	--				
	10:45	30	-0.18	2.32	--	10.75	--				
	10:55	40	-0.18	2.07	--	10.42	--				
	11:05	50	-0.18	1.91	--	9.75	--				
	11:15	60	-0.18	1.81	--	8.76	--	-0.11			

CITY ~~OF~~ **ASTORIA**, OREGON
AQUIFER TEST

DATE 11.15.60 / 1000

SHEET 5 OF 5

DATE	TIME	ACCUM. MINUTES	BAROM. CORRECTION FROM 4:46 P.M. 9/20/60 FEET WATER	WELLS AND ZERO WATER ELEVATIONS - M.S.L.					REMARKS	
				909.18 STILLMAN		909.20 BYERS		906.16 BANK		907.18 906.16 ROUND-UP
				DRAWDOWN FEET	Q-G.P.M.	DRAWDOWN FEET	Q-G.P.M.	DRAWDOWN FEET		DRAWDOWN FEET
11/2	11:35 ^A	20	-0.20						-2.38	
	12:15 ^P	120	-0.21			6.15	-			
	1:25	130	-0.21	1.64	-				-1.07	
	1:35	140	-0.22							-2.61
	1:15	150	-0.23			5.38	-			
	1:25	160	-0.23	1.57	-				-1.21	
	1:35	170	-0.23							-2.77
	2:15	240	-0.24			4.81	-			
	2:25	250	-0.24	1.12	-				-1.46	
	2:35	260	-0.24							-2.93
	3:15	310	-0.25			4.50	-			
	3:25	320	-0.25	1.34	-				-1.54	
	3:35	330	-0.25							-3.00
	4:15	380	-0.27			4.10	-			
	4:25	370	-0.27	1.25	-				-1.59	
	4:35	350	-0.27							-3.06
	6:15	490	-0.28			3.51	-			
	6:25	480	-0.28	1.25	-				-1.78	
	6:35	500	-0.28							-3.05
	8:15	600	-0.26			3.07	-			
	8:25	610	-0.26	1.25	-				-1.83	
	8:35	620	-0.26							-3.16
	10:15	720	-0.26			2.51	-			
	10:25	730	-0.26	1.25	-				-1.86	
	10:35	740	-0.26							-3.16
11/3	8:00 ^A	1200	-0.34			1.90	-			
	8:15	1320	-0.34	0.97	-				-2.00	
	8:25	1330	-0.34							-2.49
	10:00	1425	-0.37						-2.04	215 ST. ON 9 AM.
	5:00 ^P	1845	-0.44						-2.05	STATE HOSPITAL
	6:45	1950	-0.43						-2.02	PUMP ON 4:30 PM
	10:00	2100	-0.38						0.70	STILLMAN ON.
11/4	12:15 ^A	2230	-0.36						0.88	STILLMAN OFF.
	2:00	2430	-0.34						-0.87	STATE HOSP. OFF
	4:15	2500	-0.29						-1.33	2:30 AM
	10:00	2810	-0.18						-1.86	
	12:20	2880	-0.18						-1.90	STATE HOSP. AL
	2:00 ^P	3100	-0.20						-1.90	ON AND 2:15 P OFF 12:3 P

Water Level Record

OWNER: CITY OF PENDLETON OWNER'S NO. STILLMAN #5

Description of measuring point: _____

Date 1961	Water Level Feet (above) (below) Land Surface	DATE 1962	WATER LEVEL FEET BELOW L.S.D.	Date 1962	Water Level Feet (above) (below) Land Surface	DATE	WATER LEVEL FEET BELOW L.S.D.
10-3	163.55	1-29	162.85	6-5	162.3 x	10-23	164.10 x
10-10	162.9 x	2-6	162.3 x	6-12	162.6	10-30	164.00
10-17	163.45	2-13	162.45	6-19	163.95 x	11-6	163.9 x
10-24	163.3 x	2-20	162.5	6-26	164.3	11-13	163.8
10-29	163.2	2-27	162.95 x	7-3	164.7 x	11-20	163.65 x
11-7	163.55 x	3-6	162.2 x	7-10	164.5	11-27	163.7
11-14	163.15	3-13	162.9	7-17	164.95 x	12-4	164.0 x
11-21	162.85	3-20	162.05 x	8-7	164.8 x	12-11	163.7
11-28	163.00 x	3-27	162.45	8-14	164.8	12-18	163.5 x
12-5	163.2	4-3	162.35 x	8-21	164.75 x	12-24	163.8
12-12	163.00	4-10	162.55	8-28	164.6	1963	
12-19	162.50 x	4-17	162.35	9-4	164.75 x	1-8	163.25 x
12-26	162.95	4-24	162.00 x	9-11	164.75	1-15	163.65 x
1962		4-30	162.45	9-18	164.25 x	1-29	163.5
1-2	162.8 x	5-7	162.00 x	9-25	164.45	2-5	163.5 x
1-9	163.2	5-14	162.20	10-2	164.00 x	2-12	163.75
1-16	162.75 x	5-22	162.25 x	10-9	163.7	2-21	164.2 x
1-23	162.95	5-28	162.4	10-16	164.6	2-26	163.6

REMARKS: _____

Water Level Record

#5

OWNER: City of Pendleton

OWNER'S NO. STILLMAN WELL

Description of measuring point: _____

Date	Water Level Feet (above) (below) Land Surface	Remarks	Date	Water Level Feet (above) (below) Land Surface	Remarks
			1961		
1-3-61	162.4 x		5-9	161.65 x	
1-10-61	162.2		5-16	161.7	
1-17-61	162.1		5-23	161.75 x	
1-25-61	162.25		5-30	161.85	
1-30-61	161.8 x		6-6	161.8	
2-7-61	162.1		6-13	162.7 x	
2-14-61	162.1 x		6-20	163.7	
2-21-61	161.9		7-4	163.6	
2-28-61	162.2 x		7-11	164.15 x	
3-6-61	162.2		7-25	164.25	
3-14-61	161.6 x		8-1	164.3	
3-21-61	162.1		8-22	164.4 x	
3-28-61	162.2 x		8-28	164.25	
4-4-61	162.3		9-5	164.2	
4-11-61	161.7 x		9-12	163.9 x	
4-18-61	161.3		9-19	163.85	
4-25-61	162.9 x		9-26	163.8 x	
5-2-61	161.9				

REMARKS: _____

Water Level Record

OWNER: CITY OF PENDELTON OWNER'S NO. STILLMAN #5

Description of measuring point: _____

Date -1963-	Water Level Feet (above) (below) Land Surface	DATE -1963-	WATER LEVEL FEET BELOW L.S.D.	Date -1963-	Water Level Feet (above) (below) Land Surface	DATE -1964-	WATER LEVEL FEET BELOW L.S.D.
3-5	163.5 x	7-9	165.2	1-12	164.5		163.8
3-12	163.3	7-16	165.7	11-19	163.9 x	3-24	163.8 x
3-19	163.8 x	7-23	165.9 x	11-26	164.3	4-1	164.0
3-26	163.3	7-30	165.75	12-3	164.45 x	4-7	164.0
4-2	163.4 x	8-6	165.85 x	12-10	164.6	4-15	163.8 x
4-9	163.25	8-13	165.65	12-17	164.5 x	4-21	163.9
4-16	163.2	8-20	165.75 x	12-24	164.15	4-28	163.6 x
4-23	163.4 x	8-27	165.35	-1964-	164.1 x	5-5	163.9
4-30	163.2	9-3	165.4 x	1-7	164.3	5-12	164.1 x
5-7	162.95 x	9-10	165.3	1-14	163.05 x	5-19	164.3
5-14	163.2	9-17	165.2 x	1-21	164.4	5-26	164.4 x
5-20	163.1 x	9-24	165.05	1-28	164.1 x	6-2	164.1
5-28	163.35	10-1	165.2 x	2-4	164.0	6-9	164.4
6-4	163.5 x	10-8	164.75	2-11	164.4 x	6-16	164.4 x
6-11	164.1	10-15	164.65	2-18	164.1	6-23	165.3
6-18	165.3 x	10-22	164.5 x	2-24	163.9 x	6-30	165.4 x
6-25	164.9	10-29	164.7	3-3	163.85	7-7	165.5
7-2	164.85 x	11-5	164.25 x	3-10	163.9 x	7-14	166.2 x
REMARKS:				3-17		7-21	166.9
						7-28	



Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301
(503) 986-0900
www.wrd.state.or.us

Application for
Well ID Number

Do not complete if the well already has a Well I.D Number.

I. OWNER INFORMATION

Current Owner Name (please print): City of Pendleton
Mailing Address: 500 SW Dorion Ave.
City: Pendleton State: OR Zip: 97801
Mailing Address (to send Well I.D.):
City: State: Zip:

II. WELL INFORMATION (Do not complete this section if the well report is attached.) Stillman Well #5

Township: 2 N (North/South) Range: 32 E (East/West) Section: 2
Tax Lot: 3600 County: Umatilla SW 1/4 SW 1/4
Street Address of Well: 27 SE 5th St City: Pendleton
Owner at time the well was constructed, (if known): City of Pendleton
If the property had a different street address in the past:

III. GENERAL WELL INFORMATION (Do not complete this section if the well report is attached)

Use of Well (domestic, irrigation, commercial, industrial, monitoring): municipal
Date Well Constructed: 1958 Total Well Depth: 700 ft Casing Diameter: 24"-127"
Other Information:

SUBMITTED BY (please print): Karen King
PHONE: 541-966-0249 FAX: 541-966-0251

RECEIVED BY OWRD

Well ID # L 94959

MAY 06 2013

Send application to Oregon Water Resources Department; 725 Summer St NE, Suite A; Salem, Oregon 97301-1266; fax (503) 986-0902. Applications are processed and Well I.D. Numbers are mailed every Wednesday. SALEM, OR

For Official Use Only by the Oregon Water Resources Department:
Received Date: 5-6-13 Well Log Number: UMAT 530 Well Identification #: L-94959