

RECEIVED

APR 2 1999

UMAT 53271

STATE OF OREGON WATER SUPPLY WELL REPORT WATER RESOURCES DEPT. SALEM, OREGON

WELL I.D. # L. 29184 START CARD # 120052

Instructions for completing this report are on the last page of this form.

(1) OWNER: Name Arthur Batts Address 30812 Benschel Road City Hermiston State Oregon Zip 97838

(2) TYPE OF WORK: [X] New Well [] Deepening [] Alteration [] Abandonment

(3) DRILL METHOD: [X] Rotary Air [] Rotary Mud [] Cable [] Auger [] Other

(4) PROPOSED USE: [X] Domestic [] Community [] Industrial [] Irrigation [] Thermal [] Injection [] Livestock [] Other

(5) BORE HOLE CONSTRUCTION: Special Construction approval [] Yes [X] No Depth of Completed Well 195 ft.

Table with columns for HOLE Diameter, From, To, Material, and SEAL From, To, Sacks or pounds. Includes handwritten entries for 12", 8", and 6" diameters.

How was seal placed: Method [] A [] B [X] C [] D [] E Backfill placed from ft. to ft. Material Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER: Table with columns for Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Includes handwritten entries for 8" and 6" casing.

Final location of shoe(s)

(7) PERFORATIONS/SCREENS: Table with columns for From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner.

(8) WELL TESTS: Minimum testing time is 1 hour. [] Pump [] Bailer [X] Air [] Artesian. Yield gal/min 40+ Drawdown - Drill stem at 194 Time 1 hr.

Temperature of water 57.0 Depth Artesian Flow Found Was a water analysis done? [] Yes By whom Did any strata contain water not suitable for intended use? [] Too little [] Salty [] Muddy [] Odor [] Colored [] Other Depth of strata:

(9) LOCATION OF WELL by legal description: County Umatilla Latitude Longitude Township 5 N or S Range 28 E or W. WM. Section 27 NE 1/4 SW 1/4 Tax Lot 600 Lot Block Subdivision Street Address of Well (or nearest address)

(10) STATIC WATER LEVEL: 27 ft. below land surface. Date 12-8-98 Artesian pressure lb. per square inch. Date

(11) WATER BEARING ZONES: Depth at which water was first found 192

Table with columns for From, To, Estimated Flow Rate, SWL. Includes handwritten entry for 192 to 195 ft. with flow rate 40+ and SWL 27.

(12) WELL LOG: Ground Elevation

Table with columns for Material, From, To, SWL. Includes handwritten entries for Top soil, Sand (course), Light brown clay, Brown clay, Green Hard pan (clay), Fractured Basalt, Hard black basalt, Soft black basalt, Hard black basalt.

Date started 12-7-98 Completed 12-8-98 (unbonded) Water Well Constructor Certification:

I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

Signed _____ Date _____ WWC Number _____

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above.

Signed [Signature] Date 12-10-98 WWC Number 1719