#05

STATE OF OREGON

WATER WELL REPORT

(as required by ORS 537.765)

Umat 5466

RECEIVED DEC 1 1990 WATER RESOURCES DEPT. SALEM, OREGON

5N/36E/18 bb 16942

(1) OWNER:

Owner's Well Number: 1

Name Bryan + Shawna Debeaumont

Address Rt #1 Box 6-C

City Milton Freewater State OR Zip 97862

(2) TYPE OF WORK:

☑ New Well ☐ Deepen ☐ Recondition ☐ Abandon

(3) DRILL METHOD:

☑ Rotary Air ☐ Rotary Mud ☐ Cable ☐ Other

(4) PROPOSED USE:

☑ Domestic ☐ Community ☐ Industrial ☐ Irrigation

☐ Thermal ☐ Injection ☐ Other

(5) BORE HOLE CONSTRUCTION:

Depth of Completed Well 260 ft.

Special Standards date of approval none

HOLE Diameter	From	To	SEAL Material	From	To	Amount sacks or pounds
12	0	20	Bent	0	20	1 yd
8	20	48	Cement	20	48	6
6	48	260				

How was seal placed? Method ☐ A ☐ B ☐ C ☐ D ☐ E

☐ Other

Backfill placed from ft. to ft. Material

Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER:

	Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing:	6	+1	48	250	☑	☐	☑	☐
					☐	☐	☐	☐
					☐	☐	☐	☐
					☐	☐	☐	☐
Liner:					☐	☐	☐	☐
					☐	☐	☐	☐

Final location of shoe(s)

PERFORATIONS/SCREENS:

☐ Perforations Method none

☐ Screens Type Material

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
						☐	☐
						☐	☐
						☐	☐
						☐	☐
						☐	☐
						☐	☐

(8) WELL TESTS: Minimum testing time is 1 hour

☐ Pump ☐ Bailer ☑ Air ☐ Flowing Artesian

Yield gal/min	Pumping level	Drill stem at	Time
			¼ hr
30		260	1 hr

Temperature of water 54° Depth Artesian Flow Found

Was a water analysis done? ☐ Yes By whom none

Did any strata contain water not suitable for intended use? ☐ Too little

☐ Salty ☐ Muddy ☐ Odor ☐ Colored ☐ Other

Depth of strata:

(9) LOCATION OF WELL by legal description:

County Umatilla Latitude ' " Longitude ' "

Township 5 N or S, Range 36 E or W, WM.

Section 18 NW ¼ NW ¼

Tax Lot 702 Lot Block Subdivision

Street Address of Well (or nearest address) Same

(10) STATIC WATER LEVEL:

180 ft. below land surface. Date 9-19-90

Artesian pressure lb. per square inch. Date

(11) WELL LOG:

Ground elevation

Material	From	To	WB?	SWL
Soil + Gravel	0	8		
Gravel + Clay	8	36		
Basalt + Brn Frac	36	42		
" Gray	42	73		
Cinder Red + Brn	73	76		
Basalt Brn	76	91		
" Gray	91	147		
" Brn	147	162		
" Gray	162	246		
" Gray Frac	246	260		

Date started 8-28-90 Completed 9-19-90

(unbonded) Water Well Constructor Certification:

I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed Date

(bonded) Water Well Constructor Certification:

I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed Clarence Summers Date 10-10-90

Company C.W. Summers Well Drlg Co. Lic No.

9809C 10/85