

STATE OF OREGON WATER SUPPLY WELL REPORT

(as required by ORS 537.765)

WATER RESOURCES DEPT SALEM, OREGON

(WELL I.D.)# L L72454

(START CARD) # 168779

Instructions for completing this report are on the last page of this form.

(1) OWNER: Well Number A Name White Brothers Co. Inc. Address PO Box 683 City Walla Walla State WA Zip 99362

(2) TYPE OF WORK: [X] New Well [ ] Deepening [ ] Alteration (repair/recondition) [ ] Abandonment

(3) DRILL METHOD: [ ] Rotary Air [ ] Rotary Mud [ ] Cable [ ] Auger [X] Other Reverse Circulation Rotary

(4) PROPOSED USE: [ ] Domestic [ ] Community [ ] Industrial [X] Irrigation [ ] Thermal [ ] Injection [ ] Livestock [ ] Other

(5) BORE HOLE CONSTRUCTION: Special Construction approval [ ] Yes [X] No Depth of Completed Well 330 ft.

Table with columns: Diameter, From, To, Material, From, To, Sacks or pounds. Row 1: 20, 0, 341, Cement, 0, 88, ~475 sacks

How was seal placed: Method [ ] A [ ] B [X] C [ ] D [ ] E Backfill placed from 88 ft. to 341 ft. Material 3/8 pea

(6) CASING/LINER: Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Casing: 12, +2, 330, .375, [X]

Final location of shoe(s)

(7) PERFORATIONS/SCREENS: [X] Perforations Method Factory mill cut. Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner.

(8) WELL TESTS: Minimum testing time is 1 hour. Table with columns: Yield gal/min, Drawdown, Drill stem at, Time. Rows: 1280, 21, 1 hr; 1280, 23, 3 hours; 1280, 26, 10 hours

Temperature of water 59 F Depth Artesian Flow Found Was a water analysis done? [ ] Yes By whom Did any strata contain water not suitable for intended use? [ ] Too little

(9) LOCATION OF WELL by legal description: County Umatilla Latitude Longitude Township 6 N Range 34 E WM. Section 20 NW 1/4 NW 1/4 Tax Lot 601 Lot Block Subdivision Street Address of Well (or nearest address) 85201 White Reservoir Rd, Milton-Freewater, OR 97862

(10) STATIC WATER LEVEL: 68 ft. below land surface. Date 4/7/05 Artesian pressure lb. per square inch. Date

(11) WATER BEARING ZONES: Table with columns: From, To, Estimated Flow Rate, SWL. Row 1: 102, 309, see (8), see (10). Row 2: ???, 80, not measured, NM

(12) WELL LOG: Ground Elevation

Table with columns: Material, From, To, SWL. Rows: Loam, brown, silty (0-26); Sand, brn & blk, med-crse & grvl, 1"- w/clay (26-51); Gravel, 3"- & sand, coarse, multi-colored (51-65); Gravel, brn, 3"- w/some cobbles (65-80); Gravel, brn & blk, 2"- & sand, brn & blk, medium-coarse w/clay, brown (80-102); Sand, brn & blk, coarse w/gravel, 1.5"- (102-111); Sand, brn & blk, coarse, w/gravel, 1.5"- & occasional clay lenses (111-154); Sand, brn & blk, coarse, w/gravel, 1.5"- (154-286); Gravel, brn & blk, 1.5"- w/sand brn & blk, coarse-fine - some cementation (286-309); same as previous w/clay, tan, soft (309-312); Clay, tan, soft w/gravel, 1.5"- & sand, med (312-328); Clay, brown, med (328-333); Gravel, 1.5"- & sand, medium - multi-colored w/clay, tan, soft (333-338); Clay, brown, soft (338-341)

Date started 3/4/05 Completed 5/13/05

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief. WWC Number 1797 Signed Date 6/10/05

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief. WWC Number 649 Signed Date 6/10/05

RECEIVED JUN 14 2005 WATER RESOURCES DEPT SALEM, OREGON