



**RECEIVED**

OCT - 1 1993

WATER RESOURCES DEPT.  
SALEM, OREGON

PUMP TEST

FUJI ORCHARDS, INC.

EXEMPT WELL

Water Well: Purpose - change in use from domestic to irrigation. Test the well using the installed pump.

Location: NE1/4, Section 4, T5N, R35E.W.M., 753 feet west of northeast orner of Section 4 and south 450 feet.

Well Log: Not recorded with Water Resources Department. Date of construction is unknown.

Surface Casing - 12 inches  
Elevation - 885 feet  
Depth - 340 feet measured  
SWL - 164 feet 6 March 91 by air line

Test Pump - see attached pump sheet  
Depth set - 338 feet  
Air line set - 334 feet  
Pressure gauge - PSI with 10-foot increments  
Static reading - 73.5 PSI = 170 feet of water  
334 - 170 = 164 feet SWL

Flow Meter - McCrometer 4-inch with the least reading ten gallons

