

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED
MAR 2 - 1972

RECEIVED
APR 4 - 1972

STATE ENGINEER, SALEM, OREGON
within 30 days from the date
of well completion.

STATE ENGINEER
SALEM, OREGON

STATE OF OREGON
(Please type or print)
(Do not write above this line)

STATE ENGINEER
SALEM, OREGON

State Permit No. 2N/32-15

(1) OWNER:

Name STEVE MONOGIOUS
Address PENDLETON, OREGON

UMAT
568

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 19 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 210 ft. below land surface Date 2/23/72
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? COLUMBIA PUMP
Yield: 50 gal./min. with 50 ft. drawdown after 23 hrs.

Bailer test

gal./min. with ft. drawdown after hrs.

Artesian flow

g.p.m. Date
Temperature of water 64° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used PORTLAND CEMENT (7 SACKS)
Depth of seal 19' ft.
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County UMATILLA Driller's well number
N ¼ ¼ Section 15 T. 2 N R. 32 E W.M.

Bearing and distance from section or subdivision corner

East 300' West 700'

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 280 ft. Depth of completed well 280 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
SOIL	0	5	
SOIL & BASALT, BROKEN	5	7	
BASALT, BLACK	7	38	
BASALT, RED WITH CLAY	38	45	
BASALT, BRN	45	67	
BASALT, RED, Porous	67	77	
BASALT, BROWN, Porous	77	90	
BASALT, BRN, RED "	90	103	
BASALT, GREY, SOFT	103	143	
BASALT, BRN & RED w/ CLAY	143	178	
BASALT, GREY	178	208	
BASALT, RED, Porous	208	216	
BASALT, BROWN	216	220	
BASALT, BROKEN, RED	220	223 (CAVING)	
BASALT, GREY	223	258	
BASALT, RED, BROWN, Porous	258	278 (WATER)	
BASALT, GREY	278	280	

Work started 2-15-72 19 Completed 2-18-72 19

Date well drilling machine moved off of well 2-18 19 72

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] M. Neil Fowler Date Feb 25, 1972
(Drilling Machine Operator)

Drilling Machine Operator's License No. 709

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME PROJECT: CORPORATION
(Person, firm or corporation) (Type or print)

Address Bl. 3 Bx 134-B
MILTON-FREEWATER, ORE.

[Signed] Calvin [Signature]
(Water Well Contractor)

Contractor's License No. 512 Date Feb 25, 1972