

STATE OF OREGON
WATER SUPPLY WELL REPORT

UMAT 57128

(ORS 537.765 & OAR 690-205-0210)

Instructions for completing this report are on the last page of this form.

WELL LABEL # L 10 21 64
START CARD # 1018898
ORIGINAL LOG # N/A.

(1) LANDOWNER Owner Well I.D. #8
First Name C. Yves Pendleton Last Name _____
Company _____
Address 500 SW DORION AVE.
City Pendleton State OR Zip 97801

(2) TYPE OF WORK New Conversion Deepening
 Alteration (complete Sections 2a & 10) Abandonment (complete Section 5a)

(2a) PRE-ALTERATION: Well Depth 488 ft.
Seal Material Heat Cement
Casing Type: Steel Plastic Other _____
Casing Gauge .375 Casing Diameter 10"

(3) DRILL METHOD Rotary Air Rotary Mud Auger
 Cable Cable Mud Reverse Rotary Other _____

(4) PROPOSED USE Domestic Irrigation Community
 Industrial/Commercial Livestock Dewatering Injection
 Thermal Other _____

(5) BORE HOLE CONSTRUCTION
Depth of Completed Well 488 ft. Special Standard: Yes (attach copy)

BORE HOLE			SEAL				
Dia	From	To	Material	From	To	Amount	Scks/lbs
10"	+2	50'	cement	80	0	2.6 yards	

How was seal placed: Method A B C D E
 Other Used cementing shoe and circulated cement
Backfill placed from _____ ft. to _____ ft. Material _____
Filter pack from _____ ft. to _____ ft. Material _____ Size _____

(5a) ABANDONMENT USING UNHYDRATED BENTONITE:
Calculated Amount Proposed to be Used: _____ sacks/lbs
Actual Amount Used: _____ sacks/lbs

(6) CASING/LINER

Csng	Lnr	Dia	+	From	To	Gauge	Steel	Plastic	Welded	Thrd
X		10		2	50	.375	X		X	

Shoe Inside Outside Other Location of shoe(s) _____
Temporary casing Yes Diameter _____ From _____ To _____

(7) PERFORATIONS/SCREENS

Perf	Scrn	Csng	Lnr	Screen Dia	From	To	Screen/slot width	Slot length	# of slots	Tele/pipe size

(8) WELL TESTS: Minimum testing time is 1 hour
 Pump Bailer Air Flowing Artesian
Yield gal/min 30 Drawdown 0 Drill stem/Pump depth _____ Duration (hr) 1
Temperature 68 °F Lab analysis Yes By _____
Water quality concerns? Yes (describe below) TDS _____ ppm

From	To	Description	Amount	Units

(9) LOCATION OF WELL (legal description)
County umatilla Twp 2 N or S Range 32 E or W W.M.
Sec 9 SE 1/4 of the NW 1/4 Tax Lot 513
Tax Map Number _____ Lot _____
Lat _____ " or _____ DMS or DD
Long _____ " or _____ DMS or DD

Street Address of Well (or nearest address)
2580 NW WestGate Drive

(10) STATIC WATER LEVEL

	Date	SWL(psi)	+	SWL (ft)
Existing Well/Pre-Alteration	12-14-12			227
Completed Well	1-14-13			225

Flowing Artesian? Yes Dry Hole? Yes
WATER BEARING ZONES Depth water was first found 227

SWL Date	From	To	Est Flow	SWL (psi)	+	SWL (ft)

(11) WELL LOG Ground Elevation

Material	From	To
Installed 10" pipe Circulated cement	+2' 80	50' 0

RECEIVED BY OWRD

FEB 04 2013

SALEM, OR

Date Started 12-14-12 completed 1-14-13

(unbonded) Water Well Constructor Certification
I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

License Number 1869 Date 1-30-13
Signed Blake Harding

(bonded) Water Well Constructor Certification
I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

License Number 1669 Date 1-30-13
Signed Jody T. Rapel
Contact Info (optional) _____