

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

U MAT
6015
RECEIVED

RECEIVED

MAY - 9 1994

6N/33E/22ca
 S.C. # 26418
 Staff Card 26418

PLEASE TYPE WATER RESOURCES DEPT.

(1) OWNER:

Name Ron Haney
 Address RT 2 Box 276
 City Milton Free Water SALEM, State OR

JUL 25 1994

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
 Rotary Mud Dug
 Cable Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Thermal: Irrigation Withdrawal Reinjection
 Other: Piezometric Grounding Test

(5) CASING INSTALLED:

Steel Plastic
 Threaded Welded
 10" Diam. from 7.1 ft. to 390 ft. Gauge 0.250

LINER INSTALLED:

Steel Plastic
 Threaded Welded

(6) PERFORATIONS:

Perforated? Yes No
 Size of perforations 3/8 in. by 1/2 in.
1.04 perforations from 277 ft. to 295 ft.
1.36 perforations from 315 ft. to 385 ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____ Model No. _____
 Type _____ Slot Size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? Driller
 Yield: 940 gal./min. with 41 ft. drawdown after 10 hrs.
 Air test gal./min. with drill stem at _____ ft. hrs.
 Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow g.p.m.
 Temperature of water 540 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Special standards: Yes No
 Well seal—Material used Cement
 Well sealed from land surface to 4.5 ft.
 Diameter of well bore to bottom of seal 16 in.
 Diameter of well bore below seal 10 in.
 Amount of sealing material 1/2 yard 35 sacks pounds
 How was cement grout placed? Tremie Bottom Top
 Was pump installed? _____ Type Sub HP 20 Depth 295 ft.
 Was a drive shoe used? Yes No Plugs _____ Size: location 310 ft.
 Did any strata contain unusable water? Yes No
 Type of Water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL by legal description:

County Umatilla NE 1/4 of Section 22 of Township 6 North, Range 33 East, WM. (Township is North or South) (Range is East or West)
 Tax Lot 100 Lot _____ Block _____ Subdivision _____

MAILING ADDRESS OF WELL (or nearest address)
RT 2 Box 276
ME Oregon

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 100 ft.
 Static level 80 ft. below land surface. Date 4-13-94
 Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 10"
 Depth drilled 418 ft. Depth of completed well 415 ft.
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
BLW silt	0	6	
Hard Pan BLW silt gravel	6	19	
Gravels + sand	19	30	
Blue clay	30	36	
Clayel + grey sticky clay	36	38	
Gravel BLW silt	38	42	
Cemented Gravel 6-8" B.H.S	42	58	
Small Gravel BLW silt	58	67	
Cemented Gravel	67	98	
WB med soft cemented	98	105	80
BLW TAN silt 1-4" gravel	105	120	
WB cemented BLW gravel	120	132	
med Hard silt BLW	132	140	
BLW silt cemented Gravels	140	170	
BLW silt cemented Gravels	170	207	
BLW silt cemented Gravels	207	232	
Tan silt cemented Gravels	232	265	
Blue Grey Clay	265	277	
BLW silt & Gravel	277	280	
Cement Gravel silt loss	280	300	
BLW sticky silt	300	320	

Date work started 1-2-94 /completed 4-10-94
 Date well drilling machine moved off of well 4-13-94

(unbonded) Water Well Constructor Certification (if applicable):
 This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] _____ Date _____, 19 _____

(bonded) Water Well Constructor Certification:
 Bond 8151008462461A (number) Atena (Surety Company Name)
 On behalf of Pro-Drill Inc (typed, print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 (Signed) [Signature] (Water Well Constructor) 756
 (Dated) 4-13-94

NOTICE TO WATER WELL CONSTRUCTOR
 The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
 SALEM, OREGON 97310
 within 30 days from the date of well completion. SP#46866-690

