

RECEIVED
OCT 15 1959
STATE ENGINEER
WATER WELL REPORT
STATE OF OREGON
UMAT 6127

To State Eng'g
2/32-10M
State Well No. G1534
State Permit No. G1534

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

(1) OWNER:

Name Albertson's Food Center
Address Pendleton, Ore

(2) LOCATION OF WELL:

County Wheatis Owner's number, if any—
1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded 3/4
6" Diam. from 16 ft. to ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used

SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name
Type Model No.
a. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 16 ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off above new cement rock

(10) WATER LEVELS:

Static level 55 ft. below land surface Date
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Date, 19.....
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: 75 gal./min. with 4.5 ft. drawdown after hrs.

" " " " " " " " " "

Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 6 inches.

Depth drilled ft. Depth of completed well 356 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Black Basalt	16	120
Broken "	120	235
Red and brown water formation	175	356
325		356

Work started 19..... Completed 19.....

(13) PUMP:

Manufacturer's Name Cult Pump Co.
Type Submersible H.P. 3

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME ROY T FRENCH
(Person, firm, or corporation) (Type or print)

Address P.O. 2 Box 85 Pendleton Ore

Driller's well number 107

[Signed] Roy T French
(Well Driller)

License No. 107 Date Oct 9, 1959