

The original and first copy of this report are to be filed with the

**RECEIVED**

**WATER WELL REPORT**

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

MAY 14 1979

STATE OF OREGON  
(Please type or print)

UMAT  
6190

State Well No. 6N/35E-206

State Permit No. \_\_\_\_\_

WATER RESOURCES DEPT.

Write above this line

**(1) OWNER:** SALEM, OREGON

Name PAT VOLLMER  
Address 707 NE 6TH CT  
MILTON-FREEWATER OR

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Cable  Dug   
Driven  Jetted  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:**

10" Diam. from +2 ft. to 46.5 ft. Gage 250  
8" Diam. from +2 ft. to 220 ft. Gage 250

**PERFORATIONS:**

Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations 3/4 in. by 12 in.  
220 perforations from 110 ft. to 220 ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a AIR pump test made?  Yes  No If yes, by whom? DRILLER  
Yield: 150 gal./min. with 100 ft. drawdown after 1 hrs.  
Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water 64° F Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used PORTLAND CEMENT  
Well sealed from land surface to 46' ft.  
Diameter of well bore to bottom of seal 14 in.  
Diameter of well bore below seal 8 in.  
Number of sacks of cement used in well seal 30 sacks  
How was cement grout placed? TREMIE PIPE

Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL:**

County UMATILLA Driller's well number \_\_\_\_\_  
NW 1/4 Section 20 T. 6N R. 35E W.M.  
Bearing and distance from section or subdivision corner  
T27 LOT 400

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 110 ft.  
Static level 66 ft. below land surface. Date \_\_\_\_\_  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing \_\_\_\_\_  
Depth drilled 220 ft. Depth of completed well 220 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SOLL	0	6	
SAND	6	35	
GRAVEL	35	110	
GRAVEL w/H2O	110	220	

**RECEIVED**

JUL - 9 1979

WATER RESOURCES DEPT  
SALEM, OREGON

Work started 4-20 1979 Completed 4-24 1979  
Date well drilling machine moved off of well 4-24 1979

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Jay Bural Date 4-24, 1979  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 54-933

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Jay Bural Well Drilling  
(Person, firm or corporation) (Type or print)

Address Pendleton OR

[Signed] Jay Bural  
(Water Well Contractor)

Contractor's License No. 544 Date 4-20, 1979