

RECEIVED

MAR 20 1961 WATER WELL REPORT

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

STATE ENGINEER STATE OF OREGON (Please type or print) SALEM, OREGON

UMAT 6197

State Well No. 6N/35-20P

State Permit No.

(1) OWNER:

Name: MILTON J. ALEXANDER
Address: MILTON-FREE WATER CR# 2

(2) LOCATION OF WELL:

County: W. W. ATILLA
Section: 20 T. 6N R. 35 W.M.
Bearing and distance from section or subdivision corner: 8 FEET W. OF S.W. CORNER OR 1980 FT EAST OF S.W. CORNER OF SEC 20

(3) TYPE OF WORK (check):

New Well [ ] Deepening [X] Reconditioning [ ] Abandon [ ]
Deepening description: DEEPENING WELL

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [X] Test Well [ ] Other [ ]
Rotary [ ] Cable [ ] Dug [X] Driven [ ] Jetted [ ] Bored [ ]

(5) TYPE OF WELL:

(6) CASING INSTALLED:

8" Diam. from 12 ft. to 92 ft. Gage 1/4
Threaded [ ] Welded [X]

(7) PERFORATIONS:

Type of perforator used: ACCTYIENE TORCH
Size of perforations: 3/8 to 1/2 in. by 4 in.
150 perforations from 30 ft. to 90 ft.

(8) SCREENS:

Well screen installed [ ] Yes [X] No
Manufacturer's Name:
Slot size:
Diam. Slot size:
Work started: Sept 4 1961. Completed: Sept 12 1961

(9) CONSTRUCTION:

Well seal—Material used in seal:
Depth of seal:
Diameter of well bore to bottom of seal:
Were any loose strata cemented off? [ ] Yes [X] No
Was a drive shoe used? [ ] Yes [X] No
Was well gravel packed? [ ] Yes [X] No
Gravel placed from:
Did any strata contain unusable water? [ ] Yes [X] No
Type of water?
Method of sealing strata off:

(10) WATER LEVELS:

Static level: 26 ft. below land surface Date: Sept 12-61
Artesian pressure: lbs. per square inch Date:

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No
Yield: 650 gal./min. with 30 ft. drawdown after 6 hrs.
350 " 15 " "
250 " 7 " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 56 Was a chemical analysis made? [ ] Yes [X] No

(12) WELL LOG:

Diameter of well below casing: 8 in
Depth drilled: 72 ft. Depth of completed well: 101 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Entries include: DUG WELL TO 28 FT, CEMENT GRAVEL MED, MIXED BROWN CLAY 28-58, WATER BEARING GRAVEL MED FINE, VERY CLEAN WATER BEARING 58 98, gravel mixed brown clay med fine 95 101

(13) PUMP:

Manufacturer's Name: Pacific
Type: Centrifugal H.P. 10

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME: Lowell W. Marlett (Person, firm or corporation)
Address: R.T. #2 Box 1117A Milton Free water, Ore

Drilling Machine Operator's License No.: 265

[Signed]: Lowell W. Marlett (Water Well Contractor)

Contractor's License No.: Date: March 23, 1962