

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

SEP 1 1994

PLEASE TYPE or PRINT IN INK

Umat
6217

6N/35E/33b

Start Card 63013

(1) OWNER:

Name Jim Waliser
 Address RT 2 Box 226
 City Milton Freewater State Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
 Rotary Mud Dug
 Cable Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Thermal: Withdrawal ReInjection
 Other: Piezometric Grounding Test

3) CASING INSTALLED:

Steel Plastic
 Threaded Welded
 10" Diam. from +1 ft. to 30 ft. Gauge 0250

LINER INSTALLED:

Steel Plastic
 Threaded Welded
 8" Diam. from -22 ft. to 182 ft. Gauge Sch 40

(6) PERFORATIONS:

Perforated? Yes No liner
 Size of perforations in. by in.
 6.72 perforations from 120 ft. to 182 ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name Model No.
 Type Slot Size Set from ft. to ft.
 Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: gal./min. with ft. drawdown after hrs.
 Air test 300 gal./min. with drill stem at 180 ft. 2 hrs.
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m.
 Temperature of water 54 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No
 Well seal—Material used BentONITE
 Well sealed from land surface to 29 ft.
 Diameter of well bore to bottom of seal 1.5 1/4 in.
 Diameter of well bore below seal 10 in.
 Amount of sealing material 32 sacks pounds
 How was cement grout placed?
 Was pump installed? NO Type HP Depth ft.
 Was a drive shoe used? Yes No Plugs Size: location ft.
 Did any strata contain unusable water? Yes No
 Type of Water? depth of strata
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County UMATILLA Sec. 33 of Section 33 of Township 6 NORTH, Range 35 East, WM. (Township is North or South) (Range is East or West)
 Tax Lot Lot Block Subdivision
 MAILING ADDRESS OF WELL (or nearest address) County Road

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 68 ft.
 Static level 50 ft. below land surface. Date 9-7-94
 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 10"
 Depth drilled 192 ft. Depth of completed well 182 ft.
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Btm Soil + Gravel	0	2	
Tan silt + Boulders	2	12	
Loose Gravel Btm silt	12	16	
Btm silt cemented Gravel	16	22	
Tan silt cemented Gravel	22	68	
Brown silt cemented Gravel	68	128	50
Grey cemented Gravel			
Clean water bearing	128	180	50
Brown silt loose Gravel	180	192	50

Date work started 8-30-94 /completed 9-7-94
 Date well drilling machine moved off of well 9-7 19 94

(unbonded) Water Well Constructor Certification (if applicable):
 This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Date, 19

(bonded) Water Well Constructor Certification:
 Bond Issued by: AetNA (number) (Surety Company Name)
 On behalf of Drill Inc (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:
 (Signed) David White (Water Well Constructor)
 (Dated) 9-7-94