

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

UMH 1
631
65855

WATER WELL REPORT - 8 1966

STATE OF OREGON ENGINEER
(Please type or print)

State Well No. 2N/32-2/cbo
State Permit No.

RECEIVED

(1) OWNER: R.
Name Donald W. Hill
Address ~~3073 SW 10th~~ 2437 S.W. Olson
Pendleton Oregon

(2) LOCATION OF WELL:
County Washburn Driller's well number
1/4 Section 21 T. 2N R. 32E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): (5) TYPE OF WELL:
Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded
8" Diam. from 0 ft. to 20 1/2 ft. Gage 32.2
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cement
Depth of seal 20 ft. Was a packer used? no
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 180 ft. below land surface Date 7-6-66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 20 gal./min. with 0 ft. drawdown after 16 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 8 in
Depth drilled 320 ft. Depth of completed well 320 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Sand	0	2
Rock brown	2	27
Rock red.	27	30
Rock brown	30	34
Rock red.	34	44
" brown	44	70
Sand	70	73
rock grey hard	73	106
rock 1 Red (water bearing)	106	126
sand fine	126	129
holders + sand grey hard	129	140
holders green hard	140	178
holders grey med.	178	204
rock red	204	210
" grey	210	240
" brown	240	265
" grey	265	290
" brown	290	315
" grey	315	320

Work started May 27 1966 Completed July 6 1966
Date well drilling machine moved off of well July 7 1966

(13) PUMP:
Manufacturer's Name
Type: H.P.
Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME R.C. Allison well Drilling
(Person, firm or corporation) (Type or print)
Address P.O. Box 309-C Hermiston Ore
Drilling Machine Operator's License No. 126
[Signed] R.C. Allison
(Water Well Contractor)
Contractor's License No. 419 Date 7-7, 1966