WATER WELL REPORT

STATE OF OREGON

RECEIVED

State Well No.	64/35E-29
----------------	-----------

WATER RESOURCES DEPT
SALEM OFFICE

State Well No.	601/35E-29
State Permit No.	

(1) OWNER:	(10) LOCATION OF WELL:
Name Bud Goeuthier	County Umitilla Driller's well number
Address Rt. 2 Box 64	4 4 Section 29 T. 6N R. 35 W.M.
City Milton Freewater State Ore.	Tax Lot # 1800 Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location: Rt. 2 Box 64
New Well ☑ Deepening □ Reconditioning □ Abandon □	Milton Freewater, Ore.
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
	Depth at which water was first found - 65
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 48 ft. below land surface, Date May 80
Rotary Air 💯 Driven 🗆 Domestic 🗆 Industrial 🗆 Municipal 🗆 Rotary Mud 🗆 Dug 🖂 Irrigation 💢 Test Well 🖂 Other 🖂	Artesian pressure lbs. per square inch. Date
Bored	(12) WELL LOG: Diameter of well below casing 10"
(5) CASING INSTALLED: Steel A Plastic	Depth drilled 306 ft. Depth of completed well 306 ft.
Threaded Welded	Formation: Describe color, texture, grain size and structure of materials; and show
10""Diam. from 0 ft. to 40 ft. Gauge .0250	thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level
	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
8 Diam from 27 ft. to 3.06 ft. Gauge SCh 160	Brn soil 0 22
	Yellow clay 22 24
(6) PERFORATIONS: Perforated? I Yes No Type of perforator used Hole Saw	tan hard pan with large
Size of perforations & WW 1 in. by 1 in.	gravel 24 65
800 27 306	grey hard pan with bolders
perforations from ft. to ft.	and gravel 65 280 48WB
perforations from ft. to ft.	Blue clay with black
(E) CODYDIA	pea gravel 280 295
(7) SCREENS: Well screen installed? ☐ Yes X No	yellow hard pan with
Manufacturer's Name	small gravel 295 306 48WB
Type Model No. Diam. Slot Size Set from ft. to ft.	
Diam. Slot Size Set from ft. to ft.	
P	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Yes ☐ No. If yes, by whom? PGG	
$_{\rm eld}$: 220 $_{\rm gal./min.\ with}$ 80 $_{\rm ft.\ drawdown\ after}$ 24 $_{\rm hrs.}$	
" " " "	
Air test 300 gal./min. with drill stem at 300 ft. 2 hrs.	
Bailer test gal/min. with ft. drawdown after hrs.	
rtesian flow g.p.m.	
mperature of water 53 Depth artesian flow encountered ft.	Work started May 5 1980 Completed June 18 1980
(9) CONSTRUCTION: Special standards: Yes □ No 🛚	Date well drilling machine moved off of well June 20 19 80
Well seal—Material usedCement	Drilling Machine Operator's Certification:
Well sealed from land surface to 3.7	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of seal12 in.	and information reported above a structory, best knowledge and belief
Diameter of well bore below seal1.0 in.	[Signed] Date June 20 80
Number of sacks of cement used in well seal22	Drilling Machine Operator's License No. 1298
How was cement grout placed?pumped	W-t W-ll C
	Water Well Contractor's Certification: This well was drilled under my invisition and this was to be a few to be a
Was pump installed? Yes Type Sub HP 20 Depth ft.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location	Name Goral LaPorte well drilling
Did any strata contain unusable water? \(\text{Yes} \) No	(Type or print)
Type of Water? depth of strata	Address .Rt] .Box .101 M.F Ore
Method of sealing strata off	[Signed]
Was well gravel packed? ☐ Yes Yoo Size of gravel:	Contractor's License No.7.5.6
Gravel placed from	, 130.0.