

RECEIVED
MAY 4 1960

STATE ENGINEER WATER WELL REPORT
SALEM, OREGON STATE OF OREGON

State Well No. 2N/32-27N
State Permit No. G 1518

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

UMAT
664

(1) OWNER:

Name STANLEY G WALLULIS
Address 28 SE Byers Ave.
Pendleton, Oregon

(2) LOCATION OF WELL:

County Umatilla Owner's number, if any— W-W#1
SW 1/4 of SW 1/4 Section 27 T. 2 N R. 32 E. W.M.
Bearing and distance from section or subdivision corner
N 67° 32' 30" E a distance of
1,416.08 feet from S.W. COR OF
SECTION 27, T2N, R32E W.M.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

" Diam. from ft. to ft. Gage
8 " Diam. from 0 ft. to 49 ft. Gage Standard
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used

SIZE of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 49 ft.
Material used in seal— Cemented bottom to top
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 5 ft. below land surface Date
Artesian pressure Flows GPM lbs. per square inch Date 3/29/60

Log Accepted by:

[Signed] Stanley Wallulis Date April 28, 1960
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level. Driller

Was a pump test made? Yes No If yes, by whom?
Yield: 300 gal./min. with 130 ft. drawdown after 8 hrs.
" 250 " 95 " 6 "
" 200 " 70 " 2 "

Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow 5 g.p.m. Date 3/29/60

Temperature of water 62 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 8 inches.

Depth drilled 155 ft. Depth of completed well 155 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Soil	0	8
Gravel	8	13
Cement gravel	13	18
Soil, gravel & clay	18	27
Hardpan	27	40
Broken brown basalt	40	47
Brown basalt	47	60
Broken brown basalt	60	62
Grey basalt	62	96
Broken red & brown basalt	96	115
Brown basalt	115	143
Black basalt	143	153
(WATER BEARING)	96	153
Hard grey basalt	153	155

Work started 2/25/60 19 Completed 3/29/60 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME D K SMITH
(Person, firm, or corporation) (Type or print)

Address ROUTE 3 WALLA WALLA WASHINGTON

Driller's well number

[Signed] D K Smith
(Well Driller)

License No. 204 Date 4/25/60, 19.....