

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

UMAT
708

WATER WELL REPORT RECEIVED

STATE OF OREGON
(Please type or print)

MAR 25 1976

State Well No. 2N/32E-34

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

(Do not write above this line) WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER:

Name GERALD WYLAND
Address RT 2 Box 83
PENDLETON ORP

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Jetted
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
8" Diam. from +1 ft. to -19 ft. Gage .250
6" Diam. from +1 1/2 ft. to 3.12 ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a AIR test made? Yes No If yes, by whom?
Y: 75 gal./min. with 178 ft. drawdown after 1 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used PORTLAND CEMENT

Well sealed from land surface to 19 ft.

Diameter of well bore to bottom of seal 12 in.

Diameter of well bore below seal 8 in.

Number of sacks of cement used in well seal 12 sacks

Number of sacks of bentonite used in well seal _____ sacks

Brand name of bentonite _____

Number of pounds of bentonite per 100 gallons _____

of water _____ lbs./100 gals.

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.

Did any strata contain unusable water? Yes No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? Yes No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County UMATILLA Driller's well number 76-13
SW 1/4 SW 1/4 Section 34 T. 2N R. 32E W.M.

Bearing and distance from section or subdivision corner
LOT 4 WEST SIDE OF ROAD
FIELD CREST DIV

(11) WATER LEVEL: Completed well.

Depth at which water was first found 240 ft.

Static level 147 ft. below land surface. Date 3-21-77

Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG: Diameter of well below casing 8"

Depth drilled 375 ft. Depth of completed well 375 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SOIL	0	3	
GRAVEL CEMENTED	3	11	
CEMENT GRAVEL	11	220	
BASALT BROWN BRK	220	340	
" RED	340	345	
" BROWN	345	375	
6" LINER IS WELDED AT TOP TO 8" CASING			
8" hole was DRILLED TO 375 PUMP SHOULD NO BE SET BELOW 325'			
6' LINER COULD BE PUSHED DOWN TO 375'			

Work started 3-20 1976 Completed 3-22 1976

Date well drilling machine moved off of well 3-22 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Jerry Burd Date 9-33, 1976
(Drilling Machine Operator)

Drilling Machine Operator's License No. 933

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name LARRY BURD WELL DRILLING
(Person, firm or corporation) (Type or print)

Address P.O. Box 417 Pendleton

[Signed] Jerry Burd
(Water Well Contractor)

Contractor's License No. 544 Date 3-22, 1976