

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT
AUG 20 1970 STATE OF OREGON
(Please type or print)
RECEIVED SEP - 9 1970
STATE ENGINEER SALEM, OREGON

State Well No. 2N/32-34
State Permit No. 6-5888

(1) OWNER:

Name William Huebel
Address 4401 S.W. Lake Dr
Pendleton, Oregon 97801

UMAT
712

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
0" Diam. from 0 ft. to 20 ft. Gage 250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Water test 75 gal./min. with 45 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered " ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 5 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Umatilla Driller's well number _____
1/4 1/4 Section 34 T. 2N R. 32 E. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 61 ft.
Static level 35 ft. below land surface. Date _____
Artesian pressure lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 8
Depth drilled 110 ft. Depth of completed well 110 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	
Claystone + gravel	2	10	
Basalt	10	60	
Rock, brown - med.	60	65	Water bearing
Rock, black	65	83	
Rock, red	83	90	
Rock, black	90	95	
Rock, dark red	95	106	Water bearing
Rock, black	106	110	

Work started 8-7 1970 Completed 8-13 1970
Date well drilling machine moved off of well 8-13 1970

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Troy Griffen Date 8-13, 1970
(Drilling Machine Operator)

Drilling Machine Operator's License No. 15

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name TROY GRIFFIN
(Person, firm or corporation) (Type or print)

Address 925 HERMISTON AVE. HERMISTON ORE.

[Signed] Troy Griffen
(Water Well Contractor)

Contractor's License No. 65 Date 8-13, 1970