

UMAT
727

RECEIVED

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT MAY 10 1976

STATE OF OREGON WATER RESOURCES DEPT.

(Please type or print)

SALEM, OREGON

State Well No. 2N132E-34

Permit No.

(1) OWNER:

Name Wm. Stewart
Address Rt. 2 Box 801
Pendleton, Ore.

(2) LOCATION OF WELL:

County Umatilla Driller's well number
1/4 1/4 Section 37 T. 2N R. 32 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
12" Diam. from 0 ft. to 61 ft. Gage .330
10" Diam. from 0 ft. to 93 ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement
Depth of seal 93 ft. Was a packer used?
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 35 ft. below land surface Date
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 100 gal./min. with 0 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 10
Depth drilled ft. Depth of completed well ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Sandy soil	0	9
Cement gravel	9	14
Gravel & clay	14	48
Gravel	48	60
Rock blue	60	68
Rock brown	68	79
Rock gray	79	97
Rock blue	97	104
Rock red	104	106
Rock black	106	115
Clay brown	115	138
Rock brown	138	176
Rock gray	176	215
Rock gray hard	215	222
Rock brown	222	238
Rock red	238	262
Rock gray	262	304
Rock brown	304	356

Work started NOV. 11 1961. Completed 19
Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Ben Dreyer Drilling Contractor
(Person, firm or corporation) (Type or print)

Address Rt. 1 Bx. 225 Hermiston, Ore.

Drilling Machine Operator's License No. 12

[Signed] (Water Well Contractor)

Contractor's License No. 7 Date , 19