

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date of well completion.

**UMAT 754 WATER WELL REPORT**

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 2N/33-2cb

State Permit No. \_\_\_\_\_

**STATE ENGINEER**

**(1) OWNER: SALEM, OREGON**

Name Norman Been  
Address po. Box 626 pendleton, Ore.

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL: (4) PROPOSED USE (check):**

Rotary  Driven  Domestic  Industrial  Municipal   
 Jetted  Irrigation  Test Well  Other   
 Bored

**(5) CASING INSTALLED:** Threaded  Welded   
6" Diam. from 0 ft. to 23 ft. Gage 277  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

**(6) PERFORATIONS:** Perforated?  Yes  No.  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:** Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

**(8) WATER LEVEL: Completed well.**  
Static level 73 ft. below land surface Date 7/1/70  
 Artesian pressure lbs. per square inch Date

**(9) WELL TESTS:** Drawdown is amount water level is lowered below static level  
a pump test made?  Yes  No If yes, by whom?  
100 gal./min. with no ft. drawdown after 4 hrs.  
Pumped by "Rotary good enough"  
"to know where top of pump."  
Beller test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 57 Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**  
Well seal—Material used Cement  
Depth of seal 23 ft.  
Diameter of well bore to bottom of seal 9" in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from ft. to ft.

**(11) LOCATION OF WELL:**

County UMSTILLS Driller's well number \_\_\_\_\_  
1/4 1/4 Section 2 T. 2N. R. 33 W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(12) WELL LOG:** Diameter of well below casing 6"  
Depth drilled 346 ft. Depth of completed well 346 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Brown Soil	0	5	
Light Brown sandy	5	11	
Red & Black Rock med	11	23	
Gray Basalt B. Hard	23	58	W.
Black Honey Comed R.	58	108	W.
Gray Basalt B. Hard	108	120	
Black Honey Comed R.	120	130	Washed
Gray Basalt B. H.	130	144	
Red Rock med	144	146	
Brown med. & Blue Bentail	146	167	W.
Red Rock med	167	173	W.
Black coarse R.	173	184	
Brown Basalt B. med	184	210	
Gray Basalt B. Hard	210	238	
Brown Basalt B. med	238	241	
Gray Basalt B. Hard	241	300	
Black & Red Honey Comed	300	321	
Blue coarse Rock	321	346	Water
got maine flow of water at			
Water Raised 346			
73			

Work started 7/1/70 1970 Completed 7/13/ 1970  
Date well drilling machine moved off of well 7/13 1970

**Drilling Machine Operator's Certification:**  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Rudd W. Davis Date 7/10/ 1970  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 147

**Water Well Contractor's Certification:**  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME Rudd W. Davis  
(Person, firm or corporation) (Type or print)  
Address P.O. Box 162. m. F. Ore.  
[Signed] Rudd W. Davis  
(Water Well Contractor)

Contractor's License No. 159 Date 7/10/ 1970