

RECEIVED

UMAT 896

cb

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

JUN 15 1967 WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 ENGINEER STATE OF OREGON within 30 days from the date of well completion. SALEM, OREGON (Please type or print)

State Well No. 2N/33-B A State Permit No. G-4540

(1) OWNER:

Name Robert O. Bonkour Address Rt 1 Box 167 B Pendleton, Oregon

(2) LOCATION OF WELL:

County Umatilla Driller's well number 1/4 Section 8 T. 2N R. 33E, W.M. Bearing and distance from section or subdivision corner Tract # 11

(3) TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other [] Rotary [X] Cable [] Dug [] Driven [] Jetted [] Bored []

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 68 ft. Gage 250 Threaded [] Welded [X]

(7) PERFORATIONS:

Perforated? [] Yes [X] No Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddled clay Depth of seal 35 ft. Was a packer used? No Diameter of well bore to bottom of seal 8 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 45 ft. below land surface Date 6-1-67 Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [X] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Banner test 25 gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG: Diameter of well below casing 6"

Depth drilled 315 ft. Depth of completed well 315 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Topsoil, Gravel + Clay, Yellow clay, Clay mixed with gravel, Soft black rock, Med. black rock, Red rock, Black rock, Brown rock, Black rock, Red rock - water bearing, Hard black rock, Red porous rock/green shale, Red rock, Hard black rock, Black rocks, Black rock, Black rock - green shale, water bearing.

Work started 5-26 1967 Completed 5-31 1967 Date well drilling machine moved off of well 6-1 1967

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME TROY GRIFFIN (Person, firm or corporation) (Type or print) Address 925 HERMISTON AVE, HERMISTON ORE

Drilling Machine Operator's License No. 15

[Signed] Troy Griffin (Water Well Contractor)

Contractor's License No. 65 Date 6-1, 1967