

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT
STATE WELL NO. 2N/33-8M
STATE PERMIT NO. G-4484

(1) OWNER:
Name Norman Boem
Address 771. Box 106 444 Pendleton, Or

(2) LOCATION OF WELL:
County Umatilla Driller's well number
1/4 1/4 Section 8 T. 2N, R. 33E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED: Threaded Welded
6" Diam. from 2 ft to 67 1/2 ft Gage 277
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used Cutting Tool
Size of perforations 1/4 in. by 6"-to 8" in. length
115 perforations from 48 ft. to 69 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cement
Depth of seal 38 ft. Was a packer used? no
Diameter of well bore to bottom of seal 8"
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: 3/4 - mb.
Gravel placed from 69 ft. to 38 ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 45 ft. below land surface Date 2/17
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
Bailer test 39 gal./min. with 15 ft. drawdown after 1/2 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 51 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 135 ft. Depth of completed well 135 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Dark soil	0	3
Light tan sand soil	3	5
Brown hard pan	5	20
Brown cracked sand and clay	30	50
Gray cemented gravel	50	62 W
First water 62 ft in gravel		
Brown hard pan, cont	62	75 W
Red Rock brown soil	75	87 W
Gray Rock lenses	87	95
Black honey combed	95	115 W
Black x some gray water gravel	115	135
Bailer test water level		
held at first water bearing stratum		

Work started 2/7 1967 Completed 2/17 1967
Date well drilling machine moved off of well 2/20 1967

(13) PUMP: not shown pump will be installed later
Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Rudd W. Davis
(Person, firm or corporation) (Type or print)
Address 159 S. Columbus m-f, Or.
Drilling Machine Operator's License No. 147
[Signed] Rudd W. Davis
(Water Well Contractor)
Contractor's License No. 159 Date 2/20, 1967