

(1) OWNER:
Name Roy MORRIS
Address MEMORY LAKE MOTEL
PENDLETON, ORE.

(2) LOCATION OF WELL:
County UMATILLA Owner's number, if any—
SW 1/4 NW 1/4 Section 10 T. 2N R. 33E W.M.
Bearing and distance from section or subdivision corner
610 feet north + 440 feet
East from the West 1/4 corner
of Sec. 10. From NW 1/4 C. of Sec.
19 + 10 a bearing N36° 15' E.
757 feet.

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Residential Industrial Municipal
Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
6" Diam. from 0 ft. to 19 ft. Gage Std.
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 105 ft.
Material used in seal 0-19" pipe 19"-105" cement.
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 17 ft. below land surface Date 1/25/57
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] Roy Morris Date 2/11/1957
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? SELF.
Yield: 40 gal./min. with 6 ft. drawdown after 10 hrs.
" " " " " "
" " " " " "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 6" inches.
Depth drilled 275 ft. Depth of completed well 275 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0'	4'
CEMENT & GRAVEL	4'	19'
BASALT 1/2 P.M. WATER	19'	44'
BASALT 10 P.M. WATER	44'	92'
BASALT	92'	210'
BLUE BASALT	210'	220'
GREEN CLAY	220'	259'
POROUS ROCK + SOAP STONE	259'	275'

Well was drilled to 210' by Scot Chapman.

J. Roy Morris, drilled it to 275'

Mr. Chapman filled a log on this well to 210'

Work started 12/5/56 Completed 1/25 1957

(13) PUMP:
Manufacturer's Name
Type: none H.P.

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME (Person, firm, or corporation) (Type or print)
Address
Driller's well number
[Signed] (Well Driller)
License No. Date 19