

RECEIVED
MAY 9 1960

Union 1005
Union 1009

cad
3/31-8L2

STATE ENGINEER WATER WELL REPORT
SALEM, OREGON STATE OF OREGON G1753

State Well No.
State Permit No.

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

(1) OWNER:

Name La Grande Cemetery Main. District
Address P. O. Box 362
La Grande, Oregon

(2) LOCATION OF WELL:

County Union Owner's number, if any— 2
N.E. 1/4 S.W. 1/4 Section 8 T. 3S R. 38 E.W.M.
Bearing and distance from section or subdivision corner 1655.5
~~XXXXXXXXXXXX~~ ~~XXXXXXXXXX~~
No. and 653.8 ft. East from the S.W.
corner of the S.E. 1/4 of the S.W. 1/4 of
Section 8, Tp 3S, R38 E.W.M.

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8 " Diam. from 0 ft. to 167 ft. Gage 280
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Cutting torch
SIZE of perforations 1/8 in. by 8 in.
3/16 perforations from 89 ft. to 167 ft.
21 perforations from 21 ft. to 64 ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 13 ft. below land surface Date 4/13/60
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Lee Reynolds Date 4-17, 1960
manager (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? ..
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 36 gal./min. with 72 ft. drawdown after 3/4 hrs.
Artesian flow g.p.m. Date
Temperature of water 51 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 8 inches.
Depth drilled 186 ft. Depth of completed well 185 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Fill dirt	0	3
Topsoil	3	5
Cement Gravel	5	20
Sand	20	22
Gravel Clay fill	22	36
Gravel & Sand some water	36	38
Gravel Clay fill	38	56
Gravel & Sand some water	56	62
Coarse gravel clay fill	62	65
Gravel & sand partially cl.	65	74
Gravel & coarse sand Clay	74	95
Coarse gravel Clay fill	95	112
Sand & gravel some water	112	118
Gravel Clay fill	118	142
Blue clay some gravel	142	150
Brown clay like material	150	162
Sand & gravel prob. Water	162	166
Brown clay some gravel	166	173
Coarse gravel clay fill	173	176
Small gravel & some sand	176	179
Gravel & sand partially clay	179	185

Work started 3/22 1960 Completed 4/13 1960

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME O. C. Tandy
(Person, firm, or corporation) (Type or print)

Address North Powder, Ore.

Driller's well number 89

[Signed] O.C. Tandy
(Well Driller)

License No. 29 Date 4/13, 1960