

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

State Well No. 3/39-7

State Permit No. _____

G-4681

(1) OWNER:

Name Stanley Weishaar -
Address La Grande, Ore -

(2) LOCATION OF WELL:

County _____ Driller's well number _____
1/4 SW 1/4 Section 7 T. 3 R. 39. E W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
abandonment, describe material and procedure in Item 12.

PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
16" Diam. from -1 ft. to 394 ft. Gage 1/4
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Factory
Size of perforations 3/16 in. by 3 in.
perforations from 40 ft. to 394 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal 24" Conductor and Bentonite
Depth of seal 40 ft. Was a packer used? No
Diameter of well bore to bottom of seal 24" in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: 3/16 x 1/2
Gravel placed from Top ft. to 394 ft.
Did any strata contain unusable water? Yes No
Type of water? Good Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 3 1/2 ft. below land surface Date Dec-1-63
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? LOGAN
Yield: 2400 gal./min. with 90' ft. drawdown after 22 hrs.
" " " "
" " " "
" " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 54° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 394 ft. Depth of completed well 394 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil -	0	5
Hard PAN -	5	7
SAND & BROWN CLAY streaks	7	44
Cemented GRAVEL -	44	54
GRAVEL & Boulders	54	64
GRAVEL - SAND & CLAY -	64	128
SAND - Gravel & Boulders -	128	164
Boulders - (Large)	164	170
BROWN CLAY -	170	186
Boulders -	186	194
SAND & GRAVEL	194	208
CLAY & GRAVEL stratas	208	290
Blue CLAY -	290	308
SAND & GRAVEL	308	328
CLAY & Boulders -	328	344
BLACK SAND -	344	350
Blue CLAY & GRAVEL	350	365
SAND & GRAVEL -	365	385
Blue CLAY -	385	394

Work started AUG 12 1963 Completed JAN 8 1964

Date well drilling machine moved off of well _____ 19____

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Enloe Drilling Co
(Person, firm or corporation) (Type or print)

Address # 353 - LA GRANDE - Ore

Drilling Machine Operator's License No. 318

[Signed] Clay Logan
(Water Well Contractor)

Contractor's License No. 57 Date 1-24, 1964