

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED
SEP 20 1976

State Well No. 35/39E-204d

State Permit No. _____

WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER:

Name Lester Robinson

Address COVE OREGON

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

6" Diam. from 0 ft. to 300 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used Machine Cut
Size of perforations 3/16 in. by 3 in.
2880 perforations from 80 ft. to 158 ft.
2880 perforations from 240 ft. to 300 ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Courtright
Yield: 1850 gal./min. with 34 ft. drawdown after 12 hrs.

Baller test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.

Temperature of water 61 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 27 ft.
Diameter of well bore to bottom of seal 26 in.
Diameter of well bore below seal 26 in.
Number of sacks of cement used in well seal 5 cu yards 30 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs 16" Size: location 300 ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: 3/8"
Gravel placed from 27 ft. to 300 ft.

(10) LOCATION OF WELL:

County UNION Driller's well number 761
SE 1/4 NE 1/4 Section 20 T. 3S R. 39E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 80 ft.
Static level 9 ft. below land surface. Date 7-24-76
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 26"

Depth drilled 360 ft. Depth of completed well 300 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil brown sandy	0	21	
Clay dark (soft)	21	80	
SAND - FINE to MEDIUM	80	158	
CLAY DARK	158	240	
GRAVEL (PEASIZE) Well sorted	240	299	
CLAY DARK	299	360	

Work started 6-20 1976 Completed 7-24 1976
Date well drilling machine moved off of well 8-2 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Otto Ellsworth Date 8-15, 1976
(Drilling Machine Operator)

Drilling Machine Operator's License No. 872

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Otto Ellsworth
(Person, firm or corporation) (Type or print)

Address P.O. Box 1092 La Grande, Ore.

[Signed] Otto Ellsworth 97850
(Water Well Contractor)

Contractor's License No. 640 Date 9-1-, 1976