NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

Rona changed
1.0.7 W/m 1.39
Range changed = 39 Who state Well No. 35/38E - 30 de

State	Permit	No.	***************************************

\P'			
(1) OWNER:	(10) LOCATION OF WELL:		
Name Western States Land Company	County Union Driller's well no	umber #1	
Address 3571 Helms Drive	SW 14 SE 14 Section 30 T. 35	R. 38 E.	W.M
Jefferson, Ore. 97352	Bearing and distance from section or subdivisi		
(2) TYPE OF WORK (check):	Bearing and distance from section of subdivisi	on corner	
New Well ⊠ Deepening □ Reconditioning □ Abandon □			
If abandonment, describe material and procedure in Item 12.			
	(11) WATER LEVEL: Completed w	rell.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	11	ft
Rotary N Driven D Domestic Industrial Municipal D	Static level 11 ft. below land a	surface. Date	1/23/80
D:- Bored Irrigation Test Well Other	Artesian pressure lbs. per squar	re inch. Date	
(5) CASING INSTALLED: Threaded □ Welded ☑	(12) WELL LOG: Diameter of well 1	below casing	26"
16 "Diam. from +1 ft. to 171 ft. Gage 250	Depth drilled 175 ft. Depth of compl		71 ft.
	Formation: Describe color, texture, grain size		
	and show thickness and nature of each stratu	m and aquifer r	materiais enetrated
1) PERFORA FIONG	with at least one entry for each change of forma	tion. Report each	change in
') PERFORATIONS: Perforated? ☑ Yes ☐ No.	position of Static Water Level and indicate prin	cipai water-bear	ing strata
Type of perforator used	MATERIAL	From To	SWL
Size of perforations $3/16$ in. by 2 in.	Top Soil	0 3	
672 perforations from 41 ft. to 55 ft.	Clay tan	3 12	
1248 perforations from	Sandy clay hard	12 20	
1920 perforations from 121 ft. to 161 ft.	Clay green	20 42	
	Sand coarse and gravel	42 51	
(7) SCREENS: Well screen installed? Yes X No	Clay green	51 76	T
Manufacturer's Name	Sand and gravel	76 91	
Type Model No	Sand and clay	91 96	
Diam Slot size Set from ft. to ft.	Clay gray	96 120	
Diam Slot size Set from ft. to ft.	Sand and oravel	120 128	
(A) TYPE V PRESCRIC Drawdown is amount water level in	Clay	128 141	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Sand and gravel; trace of cla	v141 161	
Was a pump test made? Kl Yes □ No If yes, by whom? Farmore	Clay	161 175	
d: 820 gal./min. with 70 ft. drawdown after 24 hrs.	OFORIVED		
" " " "	CCUCIVE		
· · · · · · · · · · · · · · · · · · ·	W000 4 1000		
" " " "	MAR 2 4 1980		
Bailer test gal./min. with ft. drawdown after hrs.	WATER RESOURCES DEFT		
sian flow g.p.m.	CALEM OREGON		
emperature of water Depth artesian flow encountered ft.	Work started 1/22 19 80 Complete	1/23	19 80
	Date well drilling machine moved off of well	1/23	19 80
(9) CONSTRUCTION:	Date wen triming machine moved off of wen	1/23	13 0
Well seal—Material used Cement	Drilling Machine Operator's Certification:		
Well sealed from land surface toft.	This well was constructed under my Materials used and information reported		
Diameter of well bore to bottom of sealin.	best knowledge and belief.	above are uu	e to my
Diameter of well bore below seal26 in.	[Signed] (Drilling Machine Operator)	Date 3/21	19 80
Number of sacks of cement used in well seal	(Drilling Machine Operator)	766	.,
Now was cement grout placed? PUMPED	Drilling Machine Operator's License No.	ເສວ	••••
	777-4 777-77 (1444444444		
	Water Well Contractor's Certification:	` ,	
	This well was drilled under my jurisdi true to the best of my knowledge and bel		report is
Was a drive shoe used? ☐ Yes 🏋 No Plugs Size: location ft.			
Did any strata contain unusable water? 🗌 Yes 🖔 No	Name Steve Moore (Person, firm or corporation)	(Type or pr	 int)
Type of water? depth of strata	Address P. D. Drawer P. Moses		
	14	······································	. er - we dock ted. J
Method of sealing strata off	[Signed]		
Was well gravel packed? ✓ Yes No Size of gravel: 3/8-	(Water Well Contr		
Fravel placed from 18 ft to 175 ft	Contractor's License No. 628 Date	3/21	10 80