

STATE OF OREGON  
**WATER WELL REPORT**  
(as required by ORS 537.765)

1475 UNIO  
 2205

MAY 30 1989 39/39/3  
 4896 LG

WATER RESOURCES DEPT.

**(1) OWNER:** Owner's Well Number: \_\_\_\_\_  
 Name WEISHAAR FARM, INC  
 Address RT 2 BOX 2689  
 City LAGRANDE State ORE Zip 97830

**(2) TYPE OF WORK:**  
 New Well  Deepen  Recondition  Abandon

**(3) DRILL METHOD:**  
 Rotary Air  Rotary Mud  Cable  Other  
Reverse Rotary

**(4) PROPOSED USE:**  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Other

**(5) BORE HOLE CONSTRUCTION:**  
 Depth of Completed Well 187 ft.  
 Special Standards date of approval \_\_\_\_\_

HOLE		SEAL		Amount sacks or pounds
Diameter	From To	Material	From To	
2.6	0	192	0	20
		NEAT CEMENT		

How was seal placed? Method  A  B  C  D  E  
 Other \_\_\_\_\_  
 Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
 Gravel placed from 20 ft. to 192 ft. Size of gravel 3/8

**(6) CASING/LINER:**

Casing:	Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
					<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	16"	0	187	3/12	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

  

Liner:	Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Seal location of shoe(s) PLUG

**(7) PERFORATIONS/SCREENS:**  
 Perforations Method MACHINE  
 Screens Type \_\_\_\_\_ Material \_\_\_\_\_

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
67	102	1/8	60	3"		<input checked="" type="checkbox"/>	<input type="checkbox"/>
130	135	1/8	60	3"		<input type="checkbox"/>	<input type="checkbox"/>
147	187	1/8	60	3"		<input type="checkbox"/>	<input type="checkbox"/>

**(8) WELL TESTS: Minimum testing time is 1 hour**  
 Pump  Bailer  Air  Flowing Artesian  
 Yield gal/min 500 Pumping level 47' Drill stem at 185' Time 2 hrs.  
 \_\_\_\_\_ 1 hr

Temperature of water 47 Depth Artesian Flow Found \_\_\_\_\_  
 Was a water analysis done?  Yes By whom \_\_\_\_\_  
 Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other CLEAR  
 Depth of strata: \_\_\_\_\_

**(9) LOCATION OF WELL, by legal description:**  
 County UNION Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
 Township 3S N or S, Range 39E E or W, WM.  
 Section 3 Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
 Tax Lot 901 Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
 Street Address of Well (or nearest address) STANLEY CITY HIGHWAY

**(10) STATIC WATER LEVEL:**  
11 ft. below land surface. Date 5-8-1989  
 Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

**(11) WELL LOG:** Ground elevation \_\_\_\_\_

Material	From	To	WB?	SWL
Top Soil	0	2		
SANDY CLAY	2	12		
CLAY	12	22		
COURSE BROWN GRAVEL	22	28		
SAND	28	30		
SAND - GRAVEL	30	31		
SAND - GRAVEL - CLAY	31	32		
LAYERS SAND, GRAVEL SAND	32	37		
SANDY CLAY - GRAVEL	37	38		
COURSE SAND	38	40		
SANDY CLAY	40	42		
SANDY CLAY - Broken Rock	42	48		
COURSE SAND	44	56		
BLACK CLAY	56	65		
COURSE SAND	65	70		
FINE GRAVEL	70	72		
GRAVEL - COURSE SAND	72	73		
SANDSTONE	73	75		
CLAY SANDSTONE	75	80		
CLAY - GRAVEL	80	81		
COURSE SAND	81	88		
GRAVEL - COURSE SAND SANDSTONE	88	92		
SANDY CLAY - COURSE SAND	92	95		
FINE to COURSE GRAVEL	95	100		
SANDY CLAY	100	101		
COURSE SANDY CLAY	101	103		
BLACK SANDSTONE	103	104		
BLACK SHALE	104	124		
BLACK SANDY CLAY SANDSTONE	124	125		
BLACK CLAY	125	128		
BLACK COURSE SAND	128	133		

Date started 5-6-1989 Completed 5-8-1989

**(unbonded) Water Well Constructor Certification:**  
 I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.  
 Signed \_\_\_\_\_ Date \_\_\_\_\_

**(bonded) Water Well Constructor Certification:**  
 I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.  
 Signed Wade Lorne Date 5-8-89  
 Company Lorne Well Drilling Co. Job No. WWC 1399

STATE OF OREGON  
WATER WELL REPORT  
(as required by ORS 537.765)

MAY 30 1989

(1) OWNER: Owner's Well Number: \_\_\_\_\_

Name WELSHAAR FARM, INC

Address \_\_\_\_\_

City LA GRANDE State ORE. Zip 97850

(2) TYPE OF WORK:

New Well  Deepen  Recondition  Abandon

(3) DRILL METHOD:

Rotary Air  Rotary Mud  Cable  Other

(4) PROPOSED USE:

Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Other

(5) BORE HOLE CONSTRUCTION:

Depth of Completed Well \_\_\_\_\_ ft.

Special Standards date of approval \_\_\_\_\_

HOLE Diameter	From		To	SEAL Material		From	To	Amount sacks or pounds

How was seal placed? Method  A  B  C  D  E

Other

Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_

Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(6) CASING/LINER:

Diameter	From		To	Gauge	Steel	Plastic	Welded	Threaded
Casing:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Liner:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Location of shoe(s) \_\_\_\_\_

(7) PERFORATIONS/SCREENS:

Perforations Method \_\_\_\_\_

Screens Type \_\_\_\_\_ Material \_\_\_\_\_

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour

Pump  Bailer  Air  Flowing  Artesian

Yield gal/min \_\_\_\_\_ Pumping level \_\_\_\_\_ Drill stem at \_\_\_\_\_ Time \_\_\_\_\_

\_\_\_\_\_ 1 hr

Temperature of water \_\_\_\_\_ Depth Artesian Flow Found \_\_\_\_\_

Was a water analysis done?  Yes By whom \_\_\_\_\_

Did any strata contain water not suitable for intended use?  Too little

Salty  Muddy  Odor  Colored  Other \_\_\_\_\_

Depth of strata: \_\_\_\_\_

(9) LOCATION OF WELL by legal description:

WATER RESOURCES DEPT.  
SALEM, OREGON

County \_\_\_\_\_ Latitude \_\_\_\_\_ Longitude \_\_\_\_\_

Township 3S N or S, Range 39E E or W, WM.

Section 3 1/4 1/4

Tax Lot 901 Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_

Street Address of Well (or nearest address) ISLAND CITY Highway

(10) STATIC WATER LEVEL:

\_\_\_\_\_ ft. below land surface. Date \_\_\_\_\_

Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

(11) WELL LOG: Ground elevation \_\_\_\_\_

Material	From	To	WB?	SWL
SAND STONE	133	136		
FINE BLACK SAND	136	140		
FINE BLACK SAND-SAND STONE	140	143		
BLACK SANDY CLAY	143	144		
BLACK SAND STONE	144	147		
BLACK SAND-CLAY-SAND STONE	147	150		
FINE TO COURSE SAND-CLAY	150	153		
COURSE SAND-gravel LAYERS	153	160		
COURSE SAND-CLAY	160	163		
LAYERS CLAY-SAND STONE	163	167		
COURSE SAND-gravel	167	174		
COURSE SAND-CLAY SAND STONE	174	177		
BLACK CLAY	177	182		
COURSE SAND	183	185		
COURSE SAND-SAND STONE	185	187		
COURSE SAND-CLAY	187	192		

Date started \_\_\_\_\_ Completed \_\_\_\_\_

(unbonded) Water Well Constructor Certification:

I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed \_\_\_\_\_ Date \_\_\_\_\_

(bonded) Water Well Constructor Certification:

I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed Walter Lowe Date 5-8-89

Company Lowe Well Drilling Co. Job No. WVC-6399