

RECEIVED

UNID 4270

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97301 within 30 days from the date of well completion.

STATE ENGINEER STATE OF OREGON (Please type or print) SALMA BRIDSON

State Well No. 2/38-23 L State Permit No.

6-7/22

(1) OWNER:

Name James E. Klein Address Rt 1 Box 188 La Grande, Ore.

(2) LOCATION OF WELL:

County Union Driller's well number NE 1/4 SW 1/4 Section 22 T. 25 R. 38 E. W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well X Deepening Reconditioning Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:

Threaded Welded 6" Diam. from 0 ft. to 89 ft. Gage 350

(7) PERFORATIONS:

Perforated? Yes X No cutting torch Size of perforations 1/8 in. by 6 in. 30 perforations from 0 ft. to 97 ft. 10 perforations from 38 ft. to 39 ft.

(8) SCREENS:

Well screen installed? Yes X No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Portland Cement Depth of seal 23 ft. Was a packer used? Diameter of well bore to bottom of seal 10 in. Were any loose strata cemented off? Yes X No Depth Was a drive shoe used? Yes X No Was well gravel packed? Yes X No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? Yes X No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 10' 7" ft. below land surface Date June 23 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? Yes X No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 50 gal./min. with 10 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water 51 Was a chemical analysis made? Yes X No

(12) WELL LOG:

Diameter of well below casing 6 Depth drilled 90 ft. Depth of completed well 89 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include SOIL BLACK, CLAY BROWN, GRAVEL COARSE CLAY, BROWN, GRAVEL MED., GRAVEL COARSE, CLAY BROWN, GRAVEL MED. WATER, BEARING, GRAVEL COARSE, BROWN, GRAVEL MED. WATER, BEARING, GRAVEL MED CLAY, BROWN, GRAVEL SMALL WATER, BEARING, CLAY GRAVEL BROWN, SMALL GRAVEL SAND, MED. WATER BEARING, GRAVEL MED. CLAY BROWN.

Work started June 16 1965 Completed June 22 1965 Date well drilling machine moved off of well June 22 1965

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME (Person, firm or corporation) (Type or print) Address 1402 H. Ave. La Grande, Ore. Drilling Machine Operator's License No. [Signed] (Water Well Contractor) Contractor's License No. 59 Date June 23, 1965