

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

**RECEIVED**  
 WATER WELL REPORT  
 MAR 25 1965  
 STATE ENGINEER

DATE OF OREGON (Please type or print)

44410 534

State Well No. 2/38-22L  
 State Permit No. G3209

(1) OWNER:

Name Jim Evers  
 Address 2713 Spruce St., La Grande Ore.

(2) LOCATION OF WELL:

County Union Driller's well number  
 1/4 1/4 Section 32 T. 2S R. 38E, W.M.  
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
 6" Diam. from 0 ft. to 89 ft. Gage 250  
 " Diam. from ft. to ft. Gage  
 " Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
 Type of perforator used  
 Size of perforations in. by in.  
 perforations from ft. to ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.

(8) SCREENS:

Well screen installed?  Yes  No  
 Manufacturer's Name  
 Model No.  
 Slot size Set from ft. to ft.  
 Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite  
 Depth of seal 22 ft. Was a packer used?  
 Diameter of well bore to bottom of seal 10 in.  
 Were any loose strata cemented off?  Yes  No Depth  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel:  
 Gravel placed from ft. to ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? depth of strata  
 Method of sealing strata off

(10) WATER LEVELS:

Static level 3'6" ft. below land surface Date Feb 20  
 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom?  
 Yield: gal./min. with ft. drawdown after hrs.  
 " " " " "  
 " " " " "  
 Bailor test 34 gal./min. with 56 ft. drawdown after 1 hrs.  
 Artesian flow g.p.m. Date  
 Temperature of water 50 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 6  
 Depth drilled 93 ft. Depth of completed well 91 1/2 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
SOIL BLACK	0	3
SOIL CLAY BROWN	3	11
GRAVEL MED. WATER BEARING	11	15
GRAVEL COARSE CLAY BROWN	15	20
GRAVEL MED. CLAY BROWN	20	31
" SAND MED	31	55
CLAY BROWN	55	64
GRAVEL COARSE CLAY BROWN GREY	64	76
GRAVEL COARSE CLAY BROWN	76	88
GRAVEL MED WATER BEARING	88	92
GRAVEL MED CLAY BROWN	92	93

Work started Jan 23 1965 Completed Feb 26 1965  
 Date well drilling machine moved off of well Feb 26 1965

(13) PUMP:

Manufacturer's Name  
 Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME O.C. Tandy (Person, firm or corporation) (Type or print)  
 Address 14034 Ave. La Grande Oregon  
 Drilling Machine Operator's License No. 6  
 [Signed] O.C. Tandy (Water Well Contractor)  
 Contractor's License No. 29 Date Feb 26, 1965