NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED FEB 23 1976 WATER RESOURCES DEPT. SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED FEB 3 - 1976 WATER RESOURCES DEPT. SALEM, OREGON

25/38/33

State Well No. .....
State Permit No. UNIO 5341

(1) OWNER:
Name Ken Berry
Address LaGrande, Oregon

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

CASING INSTALLED:
Threaded ☐ Welded ☒
12" Diam. from +1 ft. to 219 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? ☒ Yes ☐ No.
Type of perforator used Machine
Size of perforations 1/8 in. by 2½ in.
4104 perforations from 171 ft. to 219 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom Courtright
Yield: 150 gal./min. with 155 ft. drawdown after 4 hrs.
" " "
" " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Neat cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 26 in.
Diameter of well bore below seal 26 in.
Number of sacks of cement used in well seal 60 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☒ Yes ☐ No Size of gravel: 3/8"
Gravel placed from 18 ft. to 219 ft.

(10) LOCATION OF WELL:
County Union Driller's well number
SE ¼ NW ¼ Section 33 T. 2 S. R. 38 E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 9 ft.
Static level 9 ft. below land surface. Date 9/23/75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing
Depth drilled 219 ft. Depth of completed well 219 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top soil	0	8	
Sand gravel & cobbles	8	83	
Sand & gravel	83	84	
Sand & gravel w/clay tan	84	126	
Cemented gravel	126	140	
Sand & grav w/clay green	140	149	
Cemented gravel	149	164	
Blue clay	164	165	
Sandstone - blue	165	167	
Cemented gravel	167	210	
Sand-gravel & cobbles	210	219	

Work started 9/5 19 75 Completed 9/23 1975
Date well drilling machine moved off of well 9/23 19 75

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Steve Moore (Drilling Machine Operator) Date 1/29, 1976
Drilling Machine Operator's License No. 755

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Glen Maddox (Person, firm or corporation) (Type or print)
Address P. O. Drawer P, Moses Lake, Wa. 98837
[Signed] Glen Maddox (Water Well Contractor)
Contractor's License No. 555 Date 1/29, 1976

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119