

UNOYO 621

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON, within 30 days from the date of well completion.

RECEIVED
SEP 28 1966
WATER WELL REPORT

State Well No. 2/38-34 G
State Permit No. _____
G-3702

(1) OWNER:
Name Claude Wright
Address JAVITDALE
LA GRANDE, OREGON

(2) LOCATION OF WELL:
County UNION Driller's well number 464
SW 1/4 NE 1/4 Section 34 T. 23 R. 38 E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
Threaded Welded
8.57 (00) Diam. from 0 ft. to 121.5 ft. Gage 250
6.56 Diam. from 11.7 ft. to 311 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used MACHINE CUT
Size of perforations 1/2 in. by 3 in.
1800 perforations from _____ ft. to _____ ft.
117 perforations from _____ ft. to 311 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:
Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
D. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Well seal—Material used in seal CEMENT (TO 22')
Depth of seal (BENTONITE TO 98') Was a packer used? NO
Diameter of well bore to bottom of seal 7.56 in. (12" TO 22')
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 19 ft. below land surface Date 9/10/66
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? OWNER
Yield: 250 gal./min. with 21 ft. drawdown after 10 hrs.
" " " " "
" " " " "
" " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 56 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 7.56
Depth drilled 314 1/2 ft. Depth of completed well 311 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Cemented Gravel (Med)	115	182
CLAY BROWN	182	195
GRAVEL (Med) Cemented	195	203
GRAVEL (LARGE)	203	217
GRAVEL (Med) CEMENTED	217	226
GRAVEL (COARSE SAND)	226	238
CLAY BROWN	238	242
GRAVEL (Med) (with bearings)	242	257
CLAY BROWN SANDY	257	283
CLAY SANDY with gravel streaks	283	313
CLAY Blue	313	315

Work started 9/4/66 19 _____ Completed 9/10/ 19 66
Date well drilling machine moved off of well 9/11 19 66

(13) PUMP:
Manufacturer's Name Fairbank's
Type: SUB- H.P. 15

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Intervalley Drilling Co -
(Person, firm or corporation) (Type or print)
Address P.O. Box 471 Island City, Oregon
Drilling Machine Operator's License No. 446
[Signed] O. Ellwood
(Water Well Contractor)
Contractor's License No. 398 Date 9/12 19 66