

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

RECEIVED

APR 12 1965

WATER WELL REPORT

STATE ENGINEER

SALEM OREGON

LWMO

627

2/38-34 H

State Well No.

State Permit No.

(1) OWNER:

Name Claude Wright
Address Fruitdale La Grande, Ore.

(2) LOCATION OF WELL:

County Union Driller's well number 26
SE 1/4 NE 1/4 Section 34 T. 25 R. 38E W.M.

Bearing and distance from section or subdivision corner
From SW Corner of the NE 1/4 of Sec 34
T25 R38E 1,089' E 315' N at
right angle.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

8" Diam. from 0 ft. to 82 ft. Gage 288
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used Torch
Size of perforations 4 in. by 5 in.
400 perforations from 22 ft. to 80 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal grout
Depth of seal 19 ft. Was a packer used? sand
Diameter of well bore to bottom of seal 1.2 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? Surface depth of strata 6' to 10"
Method of sealing strata off Seal-grout

(10) WATER LEVELS:

Static level 1 ft. below land surface Date 3-22-65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "

Bailer test 50 gal./min. with 12 ft. drawdown after 3 hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water 53° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 115 ft. Depth of completed well 82 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Top soil</u>	<u>0</u>	<u>6</u>
<u>Large gravel</u>	<u>6</u>	<u>10</u>
<u>Clay & large gravel</u>	<u>10</u>	<u>19</u>
<u>Sand & gravel</u>	<u>19</u>	<u>43</u>
<u>Cemented sand & gravel</u>	<u>43</u>	<u>74</u>
<u>Brown conglomerate</u>	<u>74</u>	<u>115</u>

Work started JAN 26 1965 Completed FEB 19 1965

Date well drilling machine moved off of well FEB 22 1965

(13) PUMP:

Manufacturer's Name N.A.F.E.
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Staffel Bros Drilling Co.
(Person, firm or corporation) (Type or print)

Address Rt 2 Box 78 La Grande Ore

Drilling Machine Operator's License No. 349

[Signed] Robert W Staffel
(Water Well Contractor)

Contractor's License No. 415 Date 8-9-65, 1965