NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
NOV 6 1969
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

Unio 711

Unio 711

State Well No. 2/39-23

State Permit No.

(1) OWNER:
Name WILFRED HAMANN
Address RT 2. LA GRANDE, ORE.

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED:
Threaded ☐ Welded ☒
16.00" Diam. from 0 ft. to 300 ft. Gage .25
..." Diam. from ... ft. to ... ft. Gage ...
..." Diam. from ... ft. to ... ft. Gage ...

PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used MILL PERFORATED
Size of perforations 1/8 in. by 3 in.
160 perforations from 110 ft. to 120 ft.
160 perforations from 140 ft. to 150 ft.
1600 perforations from 160 ft. to 260 ft.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name ...
Type ... Model No. ...
Diam. ... Slot size ... Set from ... ft. to ... ft.
Diam. ... Slot size ... Set from ... ft. to ... ft.

(8) WATER LEVEL: Completed well.
Static level 15 ft. below land surface Date 9/27/69
Artesian pressure ... lbs. per square inch Date

(9) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: ... gal./min. with ... ft. drawdown after ... hrs.
" " " "
" " " "
Bailer test ... gal./min. with ... ft. drawdown after ... hrs.
Artesian flow ... g.p.m. Date
Temperature of water 58 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:
Well seal—Material used CEMENT
Depth of seal 20' ft.
Diameter of well bore to bottom of seal 22 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth ...
Was a drive shoe used? ☐ Yes ☒ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? ... depth of strata ...
Method of sealing strata off
Was well gravel packed? ☒ Yes ☐ No Size of gravel: 3/8
Gravel placed from 20 ft. to 300 ft.

(11) LOCATION OF WELL:
County UNION Driller's well number
¼ ¼ Section 33 T. 2S R. 39E W.M.
Bearing and distance from section or subdivision corner
APPROX 1310 FT. N & 10' E. OF SW CORNER OF ABOVE

(12) WELL LOG:
Diameter of well below casing 9 7/8
Depth drilled 278 ft. Depth of completed well 260 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOP SOIL	0	3	
BROWN CLAY	3	12	
GRAY SANDY CLAY, SMALL BOULDERS	12	35	
BROWN CLAY, SOME SAND	35	50	
" " GRAVEL	50	80	
BROWN SANDY CLAY	80	91	
" " " BOULDERS	91	108	
SAND & FINE GRAVEL	108	121	
BROWN CLAY, COARSE SAND	121	138	
MEDIUM GRAVEL	138	149	
BROWN SANDY CLAY	149	163	
GRAVEL	163	169	
" , CLAY STREAKS	169	199	
BLUE CLAY GRAVEL & SAND STRKS	199	218	
MEDIUM GRAVEL, SAND	218	258	15'
BLUE SANDY CLAY	258	270	

Work started 9/13 1969 Completed 9/28 1969
Date well drilling machine moved off of well 10/3 1969

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] J. Morrill (Drilling Machine Operator) Date 10/20, 1969
Drilling Machine Operator's License No. 388

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME CORRIELL & JEDGWICK (Person, firm or corporation) (Type or print)
Address BOX 249 LA GRANDE, ORE.
[Signed] J. Morrill (Water Well Contractor)
Contractor's License No. 517 Date 10/20, 1969

(USE ADDITIONAL SHEETS IF NECESSARY)