

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM, OREGON  
within 30 days from the date  
of well completion.

RECEIVED  
DEC - 9 1970  
STATE ENGINEER  
SALEM, OREGON

WATER WELL REPORT

WALL  
276  
5420

State Well No. 2/44-26d  
State Permit No. 1/44-35

(1) OWNER:

Name J D BANE  
Address Enterprise Oregon

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded   
1.0" Diam. from 0 ft. to 28 ft. Gage 250  
6" Diam. from 26 ft. to 50 ft. Gage 250

PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used torch  
Size of perforations 4 in. by 4 in.  
1.80 perforations from 21 ft. to 50 ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " " "  
" " " " " "  
Baller test 100 gal./min. with 12 ft. drawdown after 2 hrs.  
Artesian flow g.p.m.

Temperature of water 53° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite Shurry  
Well sealed from land surface to 18' ft.  
Diameter of well bore to bottom of seal 14 in.  
Diameter of well bore below seal 10 in.  
Number of sacks of cement used in well seal 3 sacks  
Number of sacks of bentonite used in well seal 3 sacks  
Brand name of bentonite Premium G.L.  
Number of pounds of bentonite per 100 gallons of water 200 lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel: ft.  
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County WALLOWA Driller's well number  
SE 1/4 NW 1/4 Section 2 T. 25 R. 44 E W.M.  
Bearing and distance from section or subdivision corner  
SE 1/4 of NW 1/4 of NE 1/4 Lot 8 Block 19  
2' west 3' north of SE corner Lot 8  
(11) WATER LEVEL: Completed well.  
Depth at which water was first found 28 ft.  
Static level 14 ft. below land surface. Date Nov 27 1970  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing  
Depth drilled 50 ft. Depth of completed well 50 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Cemented Gravel	0	27	14'
RIVER RUN GRAVEL & SAND	27	50	14'

Work started Nov 18 19 70 Completed Nov 27 1970  
Date well drilling machine moved off of well Nov 27 1970

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Robert H. Stoff Date Dec 6, 1970  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 349

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name O.C. Tandy (Person, firm or corporation) (Type or print)  
Address 1403 N. Ave. La Grande Oregon  
[Signed] O.C. Tandy (Water Well Contractor)  
Contractor's License No. 29 Date Dec 7, 1970