NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

(Please type or print)

(Do not write above this line ENGINEER

SALEM. OREGON

(1) OWNER:	(10) LOCATION OF WELL:	
Name Troy KosorT	County WALOWA Driller's well number	
Address FLorg Rouse Entropping Cre	NE 1/4 NIMA Section 4 T. 5N R. 43E	W.M.
	Bearing and distance from section or subdivision corner Block	12
(2) TYPE OF WORK (check):	62 30' 5 J5' E from NW Corne	
New Well		
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 21	##
Rotary Driven Domestic Industrial Municipal		ft.
Cable D Jetted Domestic Industrial Municipal Dug		4423
Doled D mingation of fest wen of Other	Artesian pressure lbs. per square inch. Date	<u> </u>
(5) CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well below casing	
10. " Diam. from Q ft. to 97 ft. Gage 150		
6 "Diam from 0 ft to 42 ft Gage 110	Depth drilled /28 ft. Depth of completed well /20	ft.
"Diam. fromft. Gage	Formation: Describe color, texture, grain size and structure of mate and show thickness and nature of each stratum and aquifer penet	
PERFORMANIONS	with at least one entry for each change of formation. Report each chan	nge in
(6) PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate principal water-bearing s	trata.
Type of perforator used	MATERIAL From To S	WL _
Size of perforations in. by in.	Rim Rock 0 24	·
perforations from ft. to ft.	Bouldars 24 29 2	1'_
perforations from ft. to ft.	BASALT ROCK (Grey) 29 78 2	12
perforations from ft. to ft.	Red Kock a Clay 18 83 3	5
(A) CODESTO		5
(7) SCREENS: Well screen installed? ☐ Yes Ø No		
Manufacturer's Name	•	•
Type Model No.	1.00	
Diam. Slot size Set from ft. toft.		
Diam. Slot size Set from ft. to ft.	·	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made? Ves No If yes, by whom?		*
60 gal./min. with 40 ft. drawdown after 24 hrs.		
" " "	Action to every the season of the	
<i>H</i>		
Bailer test gal./min. with ft. drawdown after hrs.		
A sian flow g.p.m.		
regrature of water 57 Depth artesian flow encounteredft.	Work started July 23 1973 Completed Hug!	19 23
(9) CONSTRUCTION:	bate wen drining machine invection of wen Hug	19 75
Well seal-Material used Lement Thurry	Drilling Machine Operator's Certification:	
Well sealed from land surface toft.	This well was constructed under my direct supervis Materials used and information reported above are true to	iion.
Diameter of well bore to bottom of seal	best knowledge and belief.	
Diameter of well bore below sealin.	[Signed] Machine Operator) Date Chull k., 1	9 <i>73</i>
Number of sacks of cement used in well sealsacks	(Drilling Machine Operator)	
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No. 349	
Brand name of bentonite	Water Well Contractor's Certification:	
Number of pounds of bentonite per 100 gallons		mî in
of waterlbs./100 gals.	This well was drilled under my jurisdiction and this reportrue to the best of my knowledge and belief.	II.f 18
Was a drive shoe used? 🗹 Yes 🗌 No Plugs Size: location ft.	Name Stoffel Bros Drilling Co.	
Did any strata contain unusable water? Yes No	(Person, firm or corporation) (Type or print)	<u></u>
Type of water? Junface depth of strata 2/ 627	Address AT & Box 3346 AA GYANDE	ne
Method of sealing strata off Surface Seak	[Signal Robert 11 Stall	
Was well gravel packed? ☐ Yes 🗹 No Size of gravel:	[Signed]	
Gravel placed from ft. to ft.	Contractor's License No. 415 Date augh, 1	923