WATER WELL REPORT STATE OF OREGON

RECEIVED
MAY 7 1981

WASTE

State Well No. 12/14-10 da

WATER RESOURCES DEP 0 2253

State Permit No.

1) OWNER:	(10) LOCATION OF WELL:
Stanley Cole	County Wasco Driller's well number 55
Address Rt. 5 Box 119 A, The Dalles, Ore. 97058	NE 4 SE 4 Section 10 T. 12 R. 1 N W.M.
Dity State	Tax Lot # 2312 Lot Blk Subdivision
2) TYPE OF WORK (check):	Address at well location: Rt. 5 Box 119 A
New Well □ Deepening □ Reconditioning □ Abandon □ If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
	Depth at which water was first found 185 ft.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 175 ft. below land surface. Date 14/3/8 1
Rotary Air 🗆 Driven 🗆 Domestic 🍒 Industrial 🗆 Municipal 🗆	Artesian pressure lbs. per square inch. Date
Rotary Mud Dug Irrigation & Test Well Other	(12) WELL LOG: Diameter of well below casing
A Just a land	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel Threaded Welded	Formation: Describe color, texture, grain size and structure of materials; and show
6" Diam. from	thickness and nature of each stratum and aquifer penetrated, with at least one entry
· · · · · · · · · · · · · · · · · · ·	for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
"Diam from	
LINER INSTALLED:	77/ 7-73
ft. to ft. Gauge	Claystone, tan firm 12 19
(6) PERFORATIONS: Perforated? ☐ Yes 🍒 No	sabdstone W/boulders brown 19 58
Type of perforator used	claystone soft tan 58 68
Size of perforations in. by in.	sandstone brown soft 68 127
, perforations from ft. to ft.	claystone tan soft 127 135
perforations from ft. to ft.	sandstone brown soft 135 157
perforations from ft. to ft.	claystone tan soft 5 157 161
(7) SCREENS: Well screen installed? Yes No	sandstone brown soft 161 170
	sandstone grey hard 170 190 185
Manufacturer's Name Type	sandstone W/boulders grey
Diam. Slot Size Set from ft. to ft.	soft 190 220 175
Diam. Slot Size Set from ft. to ft.	sandstone grew hard 220 230 175
Drawdown is smooth water level is lowered	sandstone soft grev course
(8) WELL TESTS: below static level	verry soft 230 240 175
a pump test made? Yes RNo If yes, by whom?	
Nold: gal./min. with ft. drawdown after hrs.	
И и и	
Air test gal./min. with drill stem at ft. hrs.	
Bailer test 25 gal./min. with 0 ft. drawdown after 1 hrs.	
sian flow g.p.m.	
Emperature of water 56 Depth artesian flow encountered ft.	Work started Feb. XXX 1719 81 Completed April 11 1981
(9) CONSTRUCTION: Special standards: Yes No	Date well drilling machine moved off of well April 20 1981
Well seal-Material used cement W/4% bentonite	Drilling Machine Operator's Certification:
Well sealed from land surface to 18 ft.	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of seal	and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal	[Signed] Date, 19 Date, 19
Number of sacks of cement used in well seal1.3	Drilling Machine Operator's License No. 1113
How was cement grout placed?pressure grouted	
	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was pump installed? $y \otimes z$	The same and the s
Was a drive shoe used?	(Person, firm or corporation) (Type or print)
Did any strata contain unusable water? Yes No	AddressRT. 5. Box .111, The Dalles, Oregon .97058.
Type of Water? depth of strata	[Signed]
Method of sealing strata off	571 (water wen contractin) 5
Was well gravel packed? Yes Size of gravel:	Contractor's License No
Gravel placed fromft. to ft.	