

NOTICE TO WATER WELL CONTRACTOR:

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

**RECEIVED WATER WELL REPORT**  
**STATE OF OREGON**  
 (Please type or print)  
**STATE ENGINEER**

**WASC**

002586

State Well No. 1N/13-16 9

State Permit No. \_\_\_\_\_

**(1) OWNER:**

Name Robert Bailey  
 Address 1723 E 10th Street,  
The Dalles, Oregon

**(2) LOCATION OF WELL:**

County Wasco Driller's well number \_\_\_\_\_  
S.W. ¼ S.E. ¼ Section 16 T. 1 N R. 13 E W.M.  
 Bearing and distance from section or subdivision corner  
From the S.E. corner 804 feet north, 280  
feet west to well site.

**(3) TYPE OF WORK (check):**

Well  Deepening  Reconditioning  Abandon   
 Abandonment, describe material and procedure in Item 12.

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

**(5) TYPE OF WELL:**

Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

**(6) CASING INSTALLED:**

Threaded  Welded   
6" Diam. from 0 ft. to 59 ft. Gage .250  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**(7) PERFORATIONS:**

Perforated?  Yes  No  
 Type of perforator used \_\_\_\_\_  
 Size of perforations in. by in.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) SCREENS:**

Well screen installed  Yes  No  
 Manufacturer's Name \_\_\_\_\_  
 Model No. \_\_\_\_\_  
 Diam. Slot size Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. Slot size Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used in seal cement  
 Depth of seal 59 ft. Was a packer used? \_\_\_\_\_  
 Diameter of well bore to bottom of seal 8 in.  
 Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_

**(10) WATER LEVELS:**

Static level 439 ft. below land surface Date 4/17/65  
 Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

**(11) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom?  
 Yield: gal./min. with ft. drawdown after hrs.  
 " " " " "  
 " " " " "  
 Bailer test 7 1/2 gal./min. with 46 ft. drawdown after 1 hrs.  
 Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
 Temperature of water 68 Was a chemical analysis made?  Yes  No

**(12) WELL LOG:**

Diameter of well below casing 6  
 Depth drilled 507 ft. Depth of completed well 507 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Soil, sand	0	3
Sandstone & claystone, brown	3	39
" , brown	39	108
" , brown, hard & soft	108	164
" , dark brown	164	267
" , gray, hard & soft	267	291
" , brown " "	291	313
" , gray " "	313	356
" , brown " "	356	440
" , light brown	440	507
seep water 440, main water 485-500		

Work started 3-23 19 65 Completed 4-17 19 65  
 Date well drilling machine moved off of well \_\_\_\_\_ 19 \_\_\_\_\_

**(13) PUMP:**

Manufacturer's Name \_\_\_\_\_  
 Type: \_\_\_\_\_ H.P. \_\_\_\_\_

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Dorin Wilburn  
 (Person, firm or corporation) (Type or print)

Address 812 E 7th Street, The Dalles, Oregon

Drilling Machine Operator's License No. 96

[Signed] Dorin Wilburn  
 (Water Well Contractor)

Contractor's License No. 80 Date 4-19, 1965