NOTICE TO WATER WELL CONTRACTOR
. The original and first copy of this reports are to be filed with the VE DAWERSVEILEBERORT WASSE

WATER RESOURCES DEPARTMENT 2 1980
SALEM, OREGON 97310
Within 30 days from the date RESOURCES DEMo not write above this line)
STATE OF OREGON
(Please type or print)
Of 2666
State Well No. IN 13E - 33
State Permit No.

State Well No. IN 13E -33 ba

SALEM. OREGON

(1) OWNER:	(10) LOCATION OF WELL:		
Name Albert C. McClure	County Wasco Driller's well number		
Address Rt. 2 Box 135	NE 1/4 NW 1/4 Section 33 T.1N	R. 13E W.M.	
The Dalles, Oregon 97058	Bearing and distance from section or subdivisi	on corner	
(2) TYPE OF WORK (check):			
New Well [★ Deepening □ Reconditioning □ Abandon □			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	ell	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found		
Rotary Driven Domestic Rightstrial Municipal C		146 ft. urface. Date 25Feb80	
Cable			
aragetter to receive a series	Artesian pressure lbs. per squar	e inch. Date	
(5) CASING INSTALLED: Threaded Welded Cas	(12) WELL LOG: Diameter of well below casing		
(5) CASING INSTALLED: Threaded	Depth drilled 625 ft. Depth of completed well \$3,0625 ft.		
ft. to ft. Gage ft.			
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,		
(6) PERFORATIONS: Perforated? Yes No.	with at least one entry for each change of format position of Static Water Level and indicate prin	tion. Report each change in	
		· · · · · · · · · · · · · · · · · · ·	
Type of perforator used	MATERIAL	From To SWL	
Size of perforations in. by in.	Shale	0 6	
perforations from ft. to ft.	Basalt broken brown	45 87	
perforations from ft. to ft.	Basalt gray hard Basalt soft visic.	45 87 87 87 106	
perforations from ft. to ft.	Rock maroon soft	106 114	
(7) SCREENS: Well screen installed? ☐ Yes X☐ No	Basalt gray soft	114 130	
Manufacturer's Name	Rock maroon	130 136	
Type	Basalt gray med.WB	136 170	
Diam Slot size Set from ft. to ft.	Basalt gray hard	170 186	
Diam Slot size Set from ft. to ft.	Basalt black WB	186 192	
	Basalt gray hard	192 204	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Basalt black & clay seam		
Was a pump test made? 🗌 Yes 🎽 No If yes, by whom?	Basalt gray med.	234 298	
d: gal./min. with ft. drawdown after hrs.	Basalt black & clay seam	s298 321 WB	
ogal min air test from 600' for 1"	Basalt gray med	321 388	
	Basalt black & clay seam		
hour. Posible there is more. "	Basalt gray med	398 599	
Bailer test gal./min. with ft. drawdown after hrs.	Basalt black visic. WB	599 620	
esian flow g.p.m.	Basalt gray some cracks	620 625 105	
inperature of water 68 Depth artesian flow encountered ft.	Work started 5 Feb 1980 Complete	d 25 Feb 19 80	
(9) CONSTRUCTION:	Date well drilling machine moved off of well	25 Feb 180	
Well seal—Material used Cement	Drilling Machine Operator's Certification:		
Well sealed from land surface toft.	This well was constructed under my Materials used and information reported	direct supervision.	
Diameter of well bore to bottom of sealin.	best knowledge and belief.	above are true to my	
Diameter of well bore below sealin.	[Signed] Ruhard Musican	Date 13 March 80	
Number of sacks of cement used in well seal 6 sacks	(Drilling Machine Operator)	727	
How was cement grout placed? Pipe	Drilling Machine Operator's License No.	7.5.7	
	Water Well Contractor's Certification:		
N.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Was a drive shoe used? ☐ Yes 🅇 No Plugs Size: location ft. Did any strata contain unusable water? ☐ Yes 🕌 No	Name Murray Well Drilling Inc.		
Type of water? depth of strata	(Person, firm or corporation) (Type or print) Address 3712 W 8th Street The Dalles, Ore.		
Method of sealing strata off	[Signed] Richard Murran		
Was well gravel packed? ☐ Yes 🞽 No Size of gravel:	(Water Well Contractor)		
Gravel placed from	Contractor's License No. 606 Date 1	<u>5 March , 19 8</u> 0	

WASC 2666



Last Update: 11/04/08

Oregon Water Resources Department 725 Summer Street NE, Suite A Salem Oregon 97301 (503) 986-0900 www.wrd.state.or.us

Application for Well ID Number

Do not complete if the well already has a Well I.D Number.

I. OWNER INFORMATION			
Current Owner Name (please print):			
Mailing Address: 3455			
City: The Dalles	State: OR	Zip: <u>97058</u>	
Mailing Address (to send Well I.D.):			
City:	State:	Zip:	
II. WELL INFORMATION (Do not complete this section if the well report is attached.)			
Township:/	(North/South) Range: 13	East West) Section: 33	
Tax Lot: /800	County: WASCO NE	1/4 NW 1/4	
Street Address of Well: 345	5 Three mile Road	City: The Dalles	
Owner at time the well was constructed, (if known): Albert C. McClure			
If the property had a different street ac	ddress in the past:		
Use of Well (domestic frrigation, com	mercial, industrial, monitoring): 7980 Total Well Depth:		
SUBMITTED BY (please print): Marc A Norton (OWRD) PHONE: 503-986-0841 FAX:			
Send application to Oregon Water Resources Department; 725 Summer St NE, Suite A; Salem, Oregon 97301-1266; fax (503) 986-0902. Applications are processed and Well I.D. Numbers are mailed every Wednesday.			
Received Date:	Official Use Only by the Oregon Water Resou Well Log Number: WASC 2666	rces Department: Well Identification #: 104026	