WATER WELL REPORT STATE OF OREGON

NOV 10 1981 WATER RESOURCES DEPT

002674

SALEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:
Name Albin MASZIER	County WASCO Driller's well number
Address KT L BOA 117	NW 4 NE 4 Section 34 T. 1N R. 13E W.M.
City The DAllas C State Chapm	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location:
New Well Z Deepening □ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
	Depth at which water was first found 498 ft.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 5/0 ft. below land surface. Date 10-13-8
Rotary Air Driven Domestic Landustrial Municipal	Artesian pressure lbs. per square inch. Date
ry Mud	(12) WELL LOG: Diameter of well below casing
	Depth drilled /6.5 ft. Depth of completed well /6.5 ft.
(5) CASING INSTALLED: Steel Plastic Plastic Welded	Formation: Describe color, texture, grain size and structure of materials; and show
Threaded	thickness and nature of each stratum and aquifer penetrated, with at least one entry
	for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
" Diam. from	
LINER INSTALLED:	MATERIAL From To SWL
	3012 0 3
(6) PERFORATIONS: Perforated? □ Yes Zano	BROWN Clay + Black BASEL 3 223
Type of perforator used	SAND STANE - Brown 223 260
Size of perforations in. by in.	Brown Clay & Blitch BASA 260 485
perforations from	KED BIASAIT 485 495
perforations from	Black+RED Bore Break 495 511 420
perforations from ft. to ft.	Black BAIDIT (HARD) 511 916
	Black Bores Rock 916 921
(7) SCREENS: Well screen installed? Yes	BIACK BASAIT 92/ 930
Manufacturer's Name	BIACK & BROWN BASAIT 930 938
Type Model No	BIACK BASAIT 938 1030
Diam. Slot Size Set from ft. to ft.	BIACKBASAIT & Green TAL 1030 1065 150
Diam. Slot Size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
a pump test made? Yes If yes, by whom?	
Yield: gal/min. with ft. drawdown after hrs.	
"TA	
Air test 76 gal/min. with drill stem at 104 ft. hrs.	
Bailer test gal./min. with ft. drawdown after hrs.	
sian flow g.p.m.	
Temperature of water 6 5 Depth artesian flow encountered ft.	Work started 9-24 19 8/ Completed 10-12 198/
(9) CONSTRUCTION Special standards: Yes □ No □	Date well drilling machine moved off of well 13 198/
Well seal—Material used FORT LAND CEMEN	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of seal in.	and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal	[Signed] Date 10:20, 19.8!
Number of sacks of cement used in well seal	Drilling Machine Operator's License No. 1345
How was cement grout placed?	
	Water Well Contractor's Certification:
M/2	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief; / // / , \ \ \ \ \ \ \ \ \ \ \ \ \ \ \
Was pump installed?	Name and DO Toke Well Villing
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.	(Person, firm or corporation)
Did any strata contain unusable water?	Address KT J30X Y
Type of Water? depth of strata	[Signed]
Method of sealing strata off	(Water Well Contractor)
Was well gravel packed? Yes Size of gravel: Size of gravel:	Contractor's License No. 739 Date 10-20 ,198/
Gravel placed from ft. to ft.	