

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the

WATER WELL REPORT

WATER RESOURCES DEPARTMENT  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

RECEIVED

STATE OF OREGON  
(Type or print)

State Well No. W/14E-26ca  
State Permit No. G-7258

OCT 25 1979

002708

(1) OWNER: WATER RESOURCES DEPT.

Name George HARTH SALEM, OREGON  
Address RT 03 Box 37  
The Dalles Arc 97058

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):

Rotary  Driven   
Cable  Jetted   
 Bored  Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

(5) CASING INSTALLED: Threaded  Welded

0" Diam. from ..... ft. to ..... ft. Gage .....  
....." Diam. from ..... ft. to ..... ft. Gage .....  
....." Diam. from ..... ft. to ..... ft. Gage .....

(6) PERFORATIONS: Perforated?  Yes  No.

Type of perforator used .....  
Size of perforations in. by in.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.

(7) SCREENS: Well screen installed?  Yes  No

Manufacturer's Name ..... Model No. ....  
Type .....  
Diam. Slot size Set from ..... ft. to ..... ft.  
Diam. Slot size Set from ..... ft. to ..... ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level

Is a pump test made?  Yes  No If yes, by whom? AIR TEST  
Yield: 800+ gal./min. with 645 ft. drawdown after 2 hrs.  
" Needs pump Test " " "  
" TOO MUCH WATER FOR AIR TEST " " "  
Baller test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m.

Temperature of water 60° Depth artesian flow encountered ..... ft.

(9) CONSTRUCTION:

Well seal—Material used .....  
Well sealed from land surface to ..... ft.  
Diameter of well bore to bottom of seal ..... in.  
Diameter of well bore below seal ..... in.  
Number of sacks of cement used in well seal ..... sacks  
How was cement grout placed? .....

Was a drive shoe used?  Yes  No Plugs ..... Size: location ..... ft.  
Did any strata contain unusable water?  Yes  No

Type of water? ..... depth of strata .....

Method of sealing strata off .....

Was well gravel packed?  Yes  No Size of gravel: .....

Gravel placed from ..... ft. to ..... ft.

(10) LOCATION OF WELL:

County Umatilla Driller's well number .....  
NE 1/4 SW 1/4 Section 26 T. 1N R. 14E W.M.  
Bearing and distance from section or subdivision corner .....

(11) WATER LEVEL: Completed well.

Depth at which water was first found ..... ft.  
Static level 325 ft. below land surface. Date 10/4/79  
Artesian pressure ..... lbs. per square inch. Date .....

(12) WELL LOG: Diameter of well below casing 10/8"

Depth drilled 645 ft. Depth of completed well 645 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
ROCK BLACK/DARK gray	525	560	325
ROCK BLACK porous	560	570	325
Water bearing			
ROCK BLACK HARD	570	600	325
ROCK BLACK porous	600	620	325
Water bearing			
ROCK BLACK HARD	620	645	325

RECEIVED

NOV 15 1979

WATER RESOURCES DEPT  
SALEM, OREGON

8" Hole starting @ 525 to 645

Work started Oct 1 1979 Completed Oct 3 1979  
Date well drilling machine moved off of well OCT 3 1979

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] W. Schorsen Date Oct 4, 1979  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1373

Water Well Contractor's Certification:


This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name GRANT C ROBBINS  
(Person, firm or corporation) (Type or print)

Address RT 4 Box 343 THE DALLES OREG

[Signed] Grant C Robbins  
(Water Well Contractor)

Contractor's License No. 661 Date OCT 22, 1979



*original in  
Grant Robbins' file*

**Water Resources Department**  
MILL CREEK OFFICE PARK  
555 13th STREET N.E., SALEM, OREGON 97310

RECEIVED

NOV 19 1979

WATER RESOURCES DEPT  
SALEM, OREGON

1-800-452-7813  
PHONE 378-8455

October 26, 1979

Grant C. Robbins  
Route 4, Box 343  
The Dalles, OR 97058

Dear Mr. Robbins:

I am returning a water well report on the George Harth well located in T 1N, R 14E, Section 26, Wasco County.

In section (8), Mr. Schlosser, the driller, has indicated that no well test was made. Oregon Water Well Construction Standard #61-081 requires that a bailer, air or pump test be made on every well. Please fill in the yield of the subject well after testing by one of the above methods.

The log indicates that the drilling machine was moved off the well on October 3, 1979. If the well test on the Harth well is taken care of immediately, you can return the log to the Water Resources Department before the 30 day time limit for submission of logs is up.

Sincerely,

LORRAINE M. STAHR  
Management Assistant

LMS:caw  
cc: Wayne Schlosser  
Tom Paul, Watermaster, District #3

*Dear Lorraine —  
Mr. Harth does not want to flow test until  
we completes fabrication of a new manifold  
to move water away from well site. He  
should be ready to test w/in 2 weeks. I will  
send you test results when we run test.  
until then, Grant is sending in log with an  
(over)*