

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

RECEIVED
JUL 6 1973

Well No. 2N/11E-12

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WASG
002764

STATE OF OREGON

(Please type or print)

(Do not write above this line)

STATE ENGINEER
SALEM OREGON

Permit No. Wasco County

(1) OWNER:

Name CITY OF MOSIER
Address MOSIER, ORE.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow 400 g.p.m.
Temperature of water 59° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used
Well sealed from land surface to ft.
Diameter of well bore to bottom of seal in.
Diameter of well bore below seal in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County HOOD RIVER Driller's well number 5290
SW 1/4 NE 1/4 Section 12 T. 2N R. 11E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found ft.
Static level ft. below land surface. Date
Artesian pressure 76 lbs. per square inch. Date 6/29/73

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 64 ft. Depth of completed well 404 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
MED. HARD GREY BASALT	310	356	
HARD GREY BASALT	356	368	
CRACKED GREY BASALT	368	369	
HARD GREY BASALT	369	388	
BROKEN GREY BASALT	388	393	
HARD GREY BASALT	393	397	
CRACKED GREY BASALT	397	400	
HARD GREY BASALT	400	404	

Work started JUNE 25 1973 Completed JUNE 29 1973
Date well drilling machine moved off of well JUNE 29 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Edward Schmid Date JULY 5 1973
(Drilling Machine Operator)

Drilling Machine Operator's License No. 564

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name R. STRASSER DRILLING CO
(Person, firm or corporation) (Type or print)

Address 8110 SE SUNSET LAND PORTLAND ORE

[Signed] Robert L. Strasser
(Water Well Contractor)

Contractor's License No. 10 Date JULY 5, 1973