

RECEIVED
JUL 26 1966

Glen Tracy Water Master
Walla, Ore.
79 64384
7cc
2N/12-18
002864

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE ENGINEER WATER WELL REPORT
SALEM, OREGON
STATE OF OREGON
(Please type or print)

State Well No. 2N/12-18
State Permit No.

(1) OWNER:
Name Gore Wilson Orchards
Address Mosier Ore

(2) LOCATION OF WELL:
County Wasco Driller's well number
1/4 1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:
Threaded Welded
8" Diam. from 0 ft. to 80 ft. Gage 250
6" Diam. from 0 ft. to 300 ft. Gage 250

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? Yes No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cement
Depth of seal 20 ft. Was a packer used? No
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth 15
Was a drive shoe used? Yes No 8"
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 3 FT Above land surface Date
Artesian pressure 35 lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow 115 g.p.m. Date
Temperature of water 51 Was a chemical analysis made? Yes No

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 315 ft. Depth of completed well 315 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Topsoil Red Clay	0	7
Clay + sand	7	15
Blue clay	15	75
Sand - Light	75	78
Black Basalt-Solid	78	235
Blue Tuffaceous Clay	235	261
Black Basalt	261	301
Gravel + Boulders containing water	301	315

Work started 19 Completed 6-21-66 19
Date well drilling machine moved off of well 19

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Brandt Drilling Co.
(Person, firm or corporation) (Type or print)
Address 625 Crestview Rd.
Drilling Machine Operator's License No. 189
[Signed] John Pettus
(Water Well Contractor)
Contractor's License No. 401 Date 7-24- 1966